

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE ST. GEORGE, UTAH



State of Utah-Department of Administrative Services

DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

4110 State Office Building/Salt Lake City, Utah 84114/538-3018


SCIENCE BUILDING


REMODEL


HFSArchitects


DIXIE STATE COLLEGE

ST. GEORGE, UTAH









GENERAL NOTES

1. ALL DIMENSIONS & EXISTING CONDITIONS IN AREAS OF WORK ARE TO BE FIELD VERIFIED PRIOR TO COMMENCING WORK - ANY DISCREPANCIES ARE TO BE REPORTED TO THE ARCHITECT OR ENGINEER OF RECORD PRIOR TO COMMENCING WORK.

2. PROTECT ALL AREAS & SURFACES ADJACENT TO DEMOLITION & CONSTRUCTION. PATCH & REPAIR ANY DAMAGE OR HOLES IN WALLS, CEILINGS & FLOORS RESULTING FROM THE DEMOLTION OF EXISTING ITEMS OR THE CONSTRUCTION OF NEW ITEMS.

3. NOTED AREAS INDICATED THE GENERAL EXTENT OF DEMOLITON. THE CONTRACTOR'S CHOICE OF MEANS & METHODS OF CONSTRUCTION MAY REQUIRE MORE OR LESS DEMOLITION. THE MEANS & METHODS OF DEMOLITION & CONSTRUCTION MUST BE ACCOUNTED FOR IN THE CONTRACTORS BID. ANY DEMOLITION & REPAIR TO ADJACENT SURFACES BEYOND THE AREAS INDICATED IN THE CONTRACT DOCUMENTS WILL NOT BE COMPENSATED FOR AFTER THE BID OPENING.

4. PRIOR TO THE START OF DEMOLTION, THE CONTRACTOR IS TO MEET WITH THE OWNER & ARCHITECT TO IDENTIFY ALL ITEMS TO BE DEMOLISHED & REMOVED FROM SITE, ITEMS TO BE REMOVED & RETURNED TO THE OWNER, OR ITEMS TO BE REMOVED & REINSTALLED.

5. 72-HOUR NOTICE IS REQUIRED FOR ANY UTILITY SHUT DOWN.

6. ANY REPAINTING OF SURFACES REQUIRED DUE TO DAMAGE TO FINISHES DURING DEMOLITION AND CONSTRUCTION MUST BE COMPLETE FROM CORNER TO CORNER.

7. PRIOR TO BIDDING, THE CONTRACTOR IS TO SURVEY THE EXISTING WALL CONDITIONS. ALL EXISTING NAILS, SCREWS, ABANDONED FASTENERS & HARDWARE IN THE WALLS INDICATED TO REMAIN ARE TO BE REMOVED & THE HOLES PATCHED.

PLAN DEMOLITION LEGEND

EXISTING CONCRETE FLOOR SLAB TO BE SAWCUT & DEMOLISHED,

EXISTING RISERS TO BE DEMOLISHED, TYPICAL - SEE PHOTOS OF EXISTING CONDITIONS A5 - B5/AE901 EXISTING INSTRUCTOR STATION COUNTERTOP & SINK TO BE DEMOLISHED BASE CABINET TO REMAIN, PROTECT FROM DAMAGE & PREP AS REQUIRED TO RECEIVE NEW COUNTERTOP & SINK, TYPICAL - SEE MECHANICAL & ELECTRICAL DRAWINGS FOR UTILITY MODIFICATIONS -

RECOGNIZATION TO BE DEMOLISHED, BASE CABINET TO REMAIN, PROTECT FROM DAMAGE & PREP AS REQUIRED TO RECEIVE NEW ビンスタングラングスグラングラングスタングラー COUNTERTOP, TYPICAL - SEE PHOTO OF EXISTING CONDITIONS C5/AE901

EXISTING COUNTERTOP TO BE DEMOLISHED, BASE & WALL CABINET TO

REMAIN, PROTECT FROM DAMAGE & PREP AS REQUIRED TO RECEIVE NEW EMÁZKÁZKÁZKÁZKÁZKÁZKÁZKÁZKÁZKÁZ COUNTERTOP, TYPICAL EXISTING WOOD DOOR & H.M. FRAME TO BE DEMOLISHED, TYPICAL

EXISTING CONDITIONS A5 - B5/AE901 EXISTING A/V CABINET TO BE DEMOLISHED, TYPICAL - SEE PHOTO OF EXISTING CONDITIONS A5/AE901 r----EXISTING BASE CABINET, COUNTERTOP & SINK TO BE DEMOLISHED, TYPICAL - SEE MECHANICAL & ELECTRICAL DRAWINGS FOR TERMINATING

SEE PHOTOS OF EXISTING CONDITIONS A3 - B3/AE901 L_______ EXISTING LAB BENCH, COUNTERTOP & SINKS TO BE DEMOLISHED,

TYPICAL - SEE MECHANICAL & ELECTRICAL DRAWINGS FOR TERMINATING L _____ J UTILITIES - SEE PHOTO OF EXISTING CONDITIONS A1/AE901 EXISTING FIXED LAB TABLES TO BE SALVAGED & RETURNED TO DSC - SEE PHOTO OF EXISTING CONDITIONS D6/AE901, TYPICAL - SEE ELECTRICAL DRAWINGS FOR POWER/DATA MODIFICATIONS - SEE PHOTO OF EXISTING CONDITIONS C1 - C2/AE901

A6 - B6 - C6/AE901, EPOXY RESIN COUNTERTOP & SHELF TO BE & POLISH AREAS LEVEL & SMOOTH WITH COUNTERTOP, MODIFY ENDS O SINK - MODIFY CABINET AS SHOWN IN DTL. A4/AE701 & REINSTALL

> EXISTING CHEMISTRY LAB BENCH - SEE PHOTOS OF EXISING CONDITIONS A6 - B6 - C6/AE901, EPOXY RESIN COUNTERTOP & SHELF TO BE MODIFIED, REMOVE EPOXY RESIN SHELF & SUPPORTS ABOVE COUNTERTOP IN CENTER OF BENCH - AFTER REMOVING SUPPORTS SAND & POLISH AREAS LEVEL & SMOOTH WITH COUNTERTOP, TYPICAL - SEE MECHANICAL DRAWINGS FOR UTILITY MODIFICATIONS EXISTING CABINET, COUNTERTOP & SINK TO BE DEMOLISHED, TYPICAL -SEE MECHANICAL DRAWINGS FOR TERMINATING UTILITIES - SEE PHOTO OF EXISTING CONDITION C3/AE901


PARTITION LEGEND


EXISTING EXTERIOR WALL TO REMAIN, TYPICAL EXISTING STUD WALL TO BE DEMOLISHED, TYPICAL


NEW 3-5/8" METAL STUD WALL W/ 5/8" GYPSUM BOARD BOTH SIDES TO 6" ABOVE FINISH $^{
m A}$ CEILING, BRACED TO STRUCTURE ABOVE @ 4'-0" O.C. TYPICAL NEW 3-5/8" METAL STUD FURRING (WINDOW IN-FILL) W/ 5/8" GYPSUM BOARD ON ONE SIDE & 3" BATT INSULATION, PAINT WINDOW BLACK, TYPICAL


NEW 3-5/8" METAL STUD FURRING W/ 5/8" GYPSUM BOARD ON ONE SIDE TO 6" ABOVE FINISH CEILING, BRACED TO STRUCTURE ABOVE @ 4'-0" O.C. TYPICAL


A4) 2ND FLOOR DEMO PLAN



















| | | | | | MECHANICAL | L LEGEND | | | | |
|------------------------------|------|---|---------------------------------------|------|---|---|--|-------------|---------------|-------------------------------|
| SYMBOL | ABR. | DESCRIPTION | SYMBOL | ABR. | DESCRIPTION | SYMBOL ABR. | DESCRIPTION | SYMBOL | ABR. | DESCRIPTION |
| GENERAL TERMINOLOGY AIR SIDE | | | | | | WET SIDE | | | WET SIDE CONT | |
| A | | SECTION LETTER DESIGNATION | ₩₽ | | EXISTING AIR DUCT TO BE REMOVED | | UNION | | | PITCH DOWN |
| ME-101 | | SECTION DRAWN ON THIS SHEET | \\ | | EXISTING AIR DUCT TO REMAIN | Г | MANUAL ACTUATOR (BALL, | 0 | | ELBOW UP |
| (A2) | | - DETAIL NUMBER DESIGNATION | ₩ | | NEW AIR DUCT | | BUTTERFLY, NEEDLE, ETC. VALVES) | C | | ELBOW DOWN |
| AZ | | CORRESPONDING WITH GRID LOCATION | 江草 | | RECT. TO RECT. AIR DUCT TAKE-OFF | M | ELECTRIC MOTOR ACTUATOR | | | TEE UP |
| AH | | MECHANICAL EQUIPMENT DESIGNATION | 江草 | | RECT. TO RND. AIR DUCT TAKE-OFF | — Г— | BUTTERFLY VALVE | | | TEE DOWN |
| 1 | | EQUIPMENT ITEM DESIGNATION | 江苺 | | RND. TO RND. AIR DUCT TAKE-OFF | | GATE VALVE | | | EXISTING PIPING TO BE REMOVED |
| CFM | | REGISTER, GRILL OR DIFFUSER DESIGNATION WITH BALANCING CFM LISTED | \ _ | | RECT. TAKE-OFF AT END OF MAIN | | GLOBE VALVE - STRAIGHT PATTERN | | | EXISTING PIPING TO REMAIN |
| D-1 | | BELOW | ~ | | FLEXIBLE AIR DUCT | *** | GLOBE VALVE - ANGLE PATTERN | | | NEW PIPING |
| D 4 | | GRILLE, OR LOUVER DESIGNATION WHERE | 巨計 | | LINED DUCT | <u>M</u> | MOTORIZED 2-WAY CONTROL VALVE | | | PIPE CAP OR PLUG |
| R-1 | | BALANCING NOT REQUIRE | | | VANED ELBOW | <u>M</u> | MOTORIZED 3-WAY CONTROL VALVE | | | CONCENTRIC REDUCER |
| <u> 1</u> | | REVISION DESIGNATOR AND NUMBER | | | RADIUS ELBOW | | CHECK VALVE | | | ECCENTRIC REDUCER |
| 1 | | KEY NOTE DESIGNATOR AND NUMBER | ₩ □ | | CONCENTRIC DUCT TRANSITION | PRV | PRESSURE REDUCING VALVE | —-G— | | NATURAL GAS PIPING |
| | POC | POINT OF CONNECTION | <u> </u> | | ECCENTRIC DUCT TRANSITION | CBV | CIRCUIT BALANCING VALVE | | cw | CULINARY COLD WATER |
| | POR | POINT OF REMOVAL | | | FLEXIBLE AIR DUCT CONNECTION | ———— вv | BALL VALVE | | HW | CULINARY HOT WATER |
| AFF | | ABOVE FINISHED FLOOR | \\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\ | | VOLUME DAMPER | —- ▽ — | NEEDLE VALVE | —DR— | | EQUIPMENT DRAIN |
| AP | | ACCESS PANEL | \boxtimes | | SUPPLY AIR DIFFUSER | <u> </u> | AUTOMATIC AIR VENT | -HWS- | | HEATING WATER SUPPLY |
| မူ EL. | | CENTER LINE ELEVATION | | | RETURN AIR, FRESH AIR, AND TRANSFER AIR | <u></u> □ □ □ □ □ □ □ □ □ | MANUAL AIR VENT | -HWR- | | HEATING WATER RETURN |
| INV. ELEV. | | INVERT ELEVATION | | | CEILING MOUNTED EXHAUST FAN OR EXHAUST GRILLE | | STRAINER | | | |
| GC | | GENERAL CONTRACTOR | | | RETURN OR OUTSIDE AIR DUCT UP | | STRAINER W/ PLUGGED BLOW OFF | | | |
| МС | | MECHANICAL CONTRACTOR | | | SUPPLY DUCT UP | → VTI | VENTURI | | | |
| ATC | | CONTROL CONTRACTOR | | | EXHAUST AIR INTAKE UP | O. | PRESSURE GAUGE AND GAUGE COCK - | | | |
| EC | | ELECTRICAL CONTRACTOR | | | RETURN OR OUTSIDE AIR DUCT DOWN | | WATER | | | |
| NIC | | NOT IN CONTRACT | ├ ├ ├ | | SUPPLY DUCT DOWN | | THERMOMETER AND THERMOWELL | | | |
| NTS | | NOT TO SCALE | | | EXHAUST DUCT DOWN | 11 | THE MAION THE MAION AND THE MA | | | |
| С | | COMMON | ├७ ₹ ፲ ७ | | ROUND DUCT UP | | DIRECTION OF FLOW | | | |
| NC | | NORMALLY CLOSED | H 10 | | LOWER DUCT DOWN | | | | | |
| I | | | I | | | I | | | | |

RAISE DUCT UP

AP | ACCESS PANEL

SA

RA

EA

OA

MA

NEW EQUIPMENT

SUPPLY AIR

RETURN AIR

EXHAUST AIR

OUTSIDE AIR

MIXED AIR

FRESH AIR

RELIEF AIR

LOWER DUCT DOWN

FLEXIBLE DUCT CONNECTION

PARALLEL BLADE DAMPER

OPPOSED BLADE DAMPER

EXISTING EQUIPMENT TO BE REMOVED

MECHANICAL EQUIPMENT CONTROLLED

EXISTING EQUIPMENT TO REMAIN

WALL MOUNTED THERMOSTAT

WALL MOUNTED TEMP. SENSOR

NORMALLY OPEN

GENERAL NOTES:

MG-1 MECHANICAL INFORMATION IS NOT LIMITED TO THE MECHANICAL DRAWINGS. CONTRACTOR SHALL BE RESPONSIBLE FOR INFORMATION ON ALL OTHER CONSTRUCTION DOCUMENTS INCLUDING DRAWINGS BY OTHER DISCIPLINES AND SPECIFICATIONS.

A - EACH DRAWING SHEET AND THE SPECIFICATIONS HAVE BEEN PREPARED TO SUPPLEMENT EACH OTHER AND THEY SHALL BE INTERPRETED AS AN INTEGRAL UNIT WITH ITEMS SHOWN AND NOTED ON ONE AND NOT THE OTHER BEING FURNISHED AND INSTALLED AS THOUGH SHOWN AND CALLED OUT IN ALL PLACES. ITEMS IN SPECIFICATIONS OR DRAWINGS LISTED WHICH ARE DIFFERING IN EFFICIENCY OR QUALITY SHALL BE HELD TO THE GREATEST OF: EFFICIENCY, QUALITY OR GOVERNING CODE.

B - THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR THE INSTALLATION OF THE SYSTEMS ACCORDING TO THE TRUE INTENT AND MEANING OF THE CONTRACT DOCUMENTS.

C - THE CONTRACTOR SHALL INSTALL ALL EQUIPMENT WITH PROPER SERVICE ACCESS AND CLEARANCES ACCORDING TO MANUFACTURERS RECOMMENDATIONS. THE CONTRACTOR SHALL REVIEW SUPPLIERS BID PACKAGES FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS, SCHEDULES, AND DESIGN INTENT (ALL EQUIPMENT AND METHODS). THE CONTRACTOR SHALL REMOVE AND REINSTALL CORRECTLY AT HIS OWN EXPENSE ANY EQUIPMENT NOT IN COMPLIANCE.

D - THE CONTRACTOR SHALL CONSULT MANUFACTURERS INSTALLATION INSTRUCTIONS FOR SIZES, METHODS, ACCESSORIES, AND CLEARANCES IN SPACE AVAILABLE PRIOR TO BIDDING PROJECT.

E - ANYTHING NOT CLEAR OR IN CONFLICT WILL BE EXPLAINED BY MAKING APPLICATION TO THE ENGINEER IN WRITING.

MG-2 ANY AND ALL ALTERATIONS TO THE SYSTEM SHOWN SHALL BE SUBMITTED TO THE ENGINEER PRIOR TO CHANGES FOR APPROVAL. CONTRACTOR SHALL NOT START ANY CHANGES UNTIL NOTIFIED IN WRITING. IF CHANGES ARE MADE PRIOR TO APPROVAL CONTRACTOR SHALL TAKE ALL RESPONSIBILITY FOR THE CHANGES MADE AND ALL COSTS RELATING TO FAILURE OR REPLACEMENT OF ALTERATIONS.

MG-3 CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS AND LOCATIONS, OR EXISTING PIPING, EQUIPMENT, CONNECTION POINTS ETC.

MG-4 THE WORKING DRAWINGS ARE DIAGRAMMATIC. THEY DO NOT SHOW EVERY OFFSET, BEND, OR ELBOW NECESSARY FOR THE COMPLETE INSTALLATION IN THE SPACE PROVIDED. ALL LOCATIONS FOR MECHANICAL EQUIPMENT SHALL BE FIELD VERIFIED AND COORDINATED WITH ALL DRAWINGS. THE CONTRACTOR SHALL PROVIDE OR COORDINATE WITH THE GENERAL CONTRACTOR PROVISIONS FOR CORE PG-11 ALL WATER SYSTEMS SHALL MEET THE REQUIREMENTS OF DRILLS THROUGH STRUCTURE.

MG-5 THE INSTRUCTION TO "PROVIDE" ALSO INCLUDES INSTALLATION.

MG-6 SHEET METAL DUCT SIZES SHOWN ON DRAWINGS ARE FREE AREA

MG-7 PROVIDE AND INSTALL BALANCING DAMPERS IN ALL SUPPLY AND

EXHAUST AIR BRANCH DUCTS. BALANCE TO CFM SHOWN ON PLAN. MG-8 SEE ARCHITECTURAL REFLECTED CEILING PLAN FOR EXACT LOCATION

OF DIFFUSERS AND GRILLES. MG-9 PROVIDE TURNING VANES IN ALL ELBOWS OF RECTANGULAR DUCT.

MG-10 THE CONTRACTOR SHALL ASSUME ALL RESPONSIBILITY IN HANDLING AND DISPOSING OF REFRIGERANTS, OILS, ETC. ALL SUCH MATERIALS SHALL BE HANDLED, DISPOSED, AND USED IN ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL LAWS.

1 THE MECHANICAL CONTRACTOR SHALL VERIFY MOTOR VOLTAGES WITH THE ELECTRICAL DRAWING BEFORE ORDERING MOTORIZED EQUIPMENT AND CONTROLS.

MG-12 C.F.M. LISTED IS ACTUAL AIR.

MG-13 SUPPLIERS SHALL REVIEW ALL DRAWINGS AND THE SPECIFICATIONS PRIOR TO SUBMITTING PRICES TO THE CONTRACTOR. ALL QUESTIONS AND DISCREPANCIES SHALL BE BROUGHT TO THE ENGINEERS ATTENTION PRIOR TO BIDDING.

MG-14 CONTRACTOR SHALL THOROUGHLY REVIEW AND SIGN SUBMITTALS FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS PRIOR TO ENGINEERS REVIEW. SUPPLIERS SHALL HIGHLIGHT OR MARK ALL INFORMATION REQUIRED TO SHOW COMPLIANCE TO THE SPECIFICATIONS. ALL REQUESTED EXCEPTIONS TO THE SPECIFICATIONS, OR SCHEDULES SHALL BE CLEARLY NOTED AND EXPLAINED. SUBMITTAL REVIEW AND ACCEPTANCE IS FOR DESIGN CONCEPT ONLY, AND DOES NOT AT ANY TIME RELIEVE THE CONTRACTOR OF RESPONSIBILITY TO MEET SPECIFICATIONS, CAPACITIES, OR DESIGN INTENT.

MG-15 ALL MECHANICAL SHALL BE INSTALLED AND CONFORM TO THE 2006 EDITION OF THE IMC WITH UTAH ANNOTATIONS AND STATE INSPECTORS.

MG-16 THIS CONTRACTOR SHALL BE RESPONSIBLE FOR THE DRAINING DOWN AND RE-FILLING OF ALL SYSTEMS NECESSARY TO COMPLETE THE WORK OUTLINED BY THIS PROJECT. THIS INCLUDES PROVIDING THE REQUIRED CHEMICAL TREATMENT WHEN RE-FILLING THE SYSTEM.

MG-17 ALL PIPING, MATERIALS, ETC. SHALL BE NEW AND DOMESTIC MADE.

PLUMBING GENERAL NOTES:

- PG-1 ALL PLUMBING SHALL BE INSTALLED AND CONFORM TO THE 2006 EDITION OF THE INTERNATIONAL PLUMBING CODE (IPC) WITH UTAH ANNOTATIONS AND LOCAL AUTHORITY REQUIREMENTS.
- PG-2 ALL PIPING MATERIALS SHALL MEET ALL REQUIREMENTS OF IPC AND LOCAL AUTHORITY. PLASTIC PIPING SHALL BE ALLOWED ONLY WHERE SHOWN.
- PG-3 GAS PIPING INSTALLATION SHALL BE IN STRICT ACCORDANCE WITH QUESTAR REGULATIONS, NFPA CODE REQUIREMENTS, AND STATE INSPECTORS.
- PG-4 ALL MATERIALS SHALL BE NEW AND SHALL BE DOMESTIC
- PG-5 PROVIDE VACUUM BREAKERS AND BACK FLOW PREVENTERS WHERE REQUIRED BY CODE OR WHERE THERE MAY BE ANY POSSIBLE CHANCE FOR CROSS CONTAMINATION. PREVENTERS SHALL BE INSTALLED IN ACCORDANCE WITH IPC WITH UTAH ANNOTATIONS.
- PG-6 ALL PLUMBING INFORMATION IS NOT LIMITED TO THE PLUMBING DRAWINGS. CONTRACTOR SHALL BE RESPONSIBLE FOR INFORMATION ON ALL OTHER CONSTRUCTION DOCUMENTS INCLUDING ARCHITECTURAL DRAWING, STRUCTURAL DRAWINGS, MECHANICAL DRAWINGS, AND **ELECTRICAL DRAWINGS.**
- PG-7 THE WORKING DRAWINGS ARE DIAGRAMMATIC. BECAUSE OF THE SMALL SCALE OF THE DRAWING, THEY DO NOT SHOW EVERY OFFSET, BEND OR ELBOW NECESSARY FOR THE COMPLETE INSTALLATION IN THE SPACE PROVIDED. ALL PIPING SHALL BE CHECKED AND COORDINATED WITH THE ARCHITECTURAL, STRUCTURAL, MECHANICAL, AND **ELECTRICAL DRAWINGS.**

PG-8 COORDINATE ALL PIPING AND PLUMBING EQUIPMENT WITH ALL OTHER TRADES AND/OR CONTRACTORS PRIOR TO INSTALLATION.

PG-9 ANY AND ALL ALTERATIONS TO THE SYSTEM SHOWN SHALL BE SUBMITTED TO THE ENGINEER PRIOR TO CHANGES FOR APPROVAL. CONTRACTOR SHALL NOT START ANY CHANGES UNTIL NOTIFIED IN WRITING. IF CHANGES ARE MADE PRIOR TO APPROVAL CONTRACTOR SHALL TAKE ALL RESPONSIBILITY FOR THE CHANGES MADE AND ALL COSTS RELATING TO FAILURE OR REPLACEMENT OF ALTERATIONS.

PG-10 GAS LINE FITTINGS SHALL BE STANDARD WELD OR SCREW FITTINGS WITH TAPERED REDUCERS. DO NOT USE VALVES OR UNIONS, IN GAS LINES ROUTED IN INACCESSIBLE CONCEALED SPACES.

ANSI/NSF STANDARD 61. CONCERNING METAL CONTAMINANTS IN THE WATER SYSTEM.

PG-12 WATER PIPING SHALL NOT BE ROUTED IN OUTSIDE WALLS OR ON EXTERIOR SIDE OF BUILDING INSULATION ENVELOPE.




ARCHITECTURE **INTERIORS**

PLANNING 1484 South State Street

Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT





DIXIE STATE COLLEGE SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE OF UTAH 225 S. 700 E. ST. GEORGE, UT 84770

DATE DESCRIPTION


DATE: 10 JANUARY 2008 PROJECT NO: 06163660 HFSA PROJECT NO: 0647.01 CAD DWG FILE NO: STAFF DRAWN BY: **CHECKED BY:** DESIGNED BY MECHANICAL


CONSTRUCTION DOCUMENTS

MECHANICAL AND PLUMBING GENERAL **NOTES** AND LEDGENDS

MP001

| PLUMBING | LEGEND |
|-------------------------------|---------------------------|
| MEANING | SYMBOL OR ABBREVIATION |
| HOT WATER LINE | |
| COLD WATER LINE | |
| VENT LINE | |
| WASTE LINE | |
| GAS LINE | G |
| VENT THRU ROOF | VTR |
| CONNECTION TO EXISTING PIPING | • |
| WALL CLEANOUT | wco |
| CLEANOUT | со |
| CLEANOUT TO GRADE | сотс |
| FLOOR CLEANOUT | FCO |
| BALL VALVE | Ф |
| UNION | —— I——— |
| AIR LINE | A |
| POINT OF REMOVAL | |





SHEET NOTES:

- REMOVE COMPRESSED AIR, WATER, AND GAS PIPING ABOVE TABLE TOP LEVEL.
- REMOVE ALL HOT, COLD AND GAS PIPING LOCATED UNDER CABINETS AND CAP ALL PIPING UNDER FLOOR. REMOVE ALL FAUCETS.
- REMOVE EXISTING WASTE AND VENT PIPING FROM UNDER CABINETS TO AND INCLUDING NEUTRALIZATION TANK. CAP WASTE PIPING UNDER FLOOR IN CEILING SPACE OF FIRST FLOOR.
- REMOVE WATER PIPING, FAUCET, WASTE, TRAP, VENT ETC FROM UNDER AND ABOVE CABINETRY. CAP PIPING UNDER FLOOR IN CEILING SPACE OF FIRST FLOOR.
- (5) REMOVE EXISTING GAS TURRETS AND VALVES.
- 6 EXISTING SINKS AND NEUTRALIZATION TANKS SHALL REMAIN.
- 7 ALL UTILITIES ENTER CABINETS ON NORTH END.
- (8) REMOVE EXISTING WATER AND AIR TURRETS, BASE AND VALVES.
- 9 REMOVE VACUUM BREAKERS AND RE-DO WATER PIPING TO BE ROUTED UNDER TABLE.
- PATCH HOLES IN COUNTER TOPS
 WHERE PIPING HAS BEEN REMOVED
 FOR WATER, AIR AND GAS.




HFSArchitects

ARCHITECTURE
INTERIORS
PLANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT





DIXIE STATE COLLEGE SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE OF UTAH 225 S. 700 E. ST. GEORGE, UT 84770

MARK DATE DESCRIPTION

DATE: 10 JANUARY 2008

PROJECT NO: 06163660

HFSA PROJECT NO: 0647.01

CAD DWG FILE NO:

DRAWN BY: STAFF

CHECKED BY: SW

DESIGNED BY: WP

DWG TYPE: MECHANICAL

ARCHITECTURAL PHASE:
CONSTRUCTION DOCUMENTS

SHEET TITLE


SECOND FLOOR
PLUMBING DEMOLITION
PLAN

PD102


SECOND FLOOR PLUMBING DEMOLITION PLAN

SCALE: 1/8" = 1'-0"






| DATE: | 10 JANUARY 2008 |
|--------------------|-----------------|
| PROJECT NO: | 06163660 |
| HFSA PROJECT NO: | 0647.01 |
| CAD DWG FILE NO: | |
| DRAWN BY: | STAFF |
| CHECKED BY: | SW |
| DESIGNED BY: | WP |
| DWG TYPE: | MECHANICAL |
| ARCHITECTURAL PHAS | E: |



SHEET NOTES:

- PIPING TO BE ROUTED UNDER TABLE IN BOTTOM ACCESS OF CABINETRY. SEE DETAIL D5 SHEET ME501.
- PROVIDE NEW VACUUM BREAKERS ON WATER SUPPLY TO SINKS AND TURRETS.
- $\overline{3}$ ROUTE UNDER COUNTER.
- EXISTING WATER ABOVE COUNTER SHALL BE REMOVED.
- $\langle 5 \rangle$ NEW 3/4"Ø WATER PIPING.
- 6 EXISTING WATER PIPING FROM BELOW FLOOR SHALL REMAIN.
- (7) EXISTING COUNTER TOP PENETRATION.
- NEW COUNTER TOP PENETRATION.
 CORE DRILLING BY MECHANICAL
 CONTRACTOR.
- 9 CONNECT TO EXISTING WATER PIPING AT THIS LOCATION.
- EXISTING COMPRESSED AIR AND GAS PIPING ORIGINATE UNDER THE SINK CABINET. PUNCH THROUGH EXISTING WOOD PARTITION AND ROUTE NEW 3/4"Ø PIPING UNDER COUNTER. PATCH EXISTING OPENINGS IN COUNTER TOP. TWO PER TABLE.
- RELOCATE EXISTING NEUTRALIZATION
 TANK NORTH AS SHOWN. CUT NEW 2"Ø
 HOLE IN BOTTOM OF EXISTING TROUGH
 DRAIN CIW STRAINER. EXTEND NEW
 2"Ø ACID RESISTANT PIPING TO
 EXISTING RELOCATED TANK. EXTEND
 DRAIN LINE FROM NEW RELOCATED
 TANK TO EXISTING DROP THROUGH
 FLOOR.
- CONNECT TO EXISTING WASTE AND VENT UNDER COUNTER



HFSArchitects


ARCHITECTURE INTERIORS PLANNING

1484 South State Street

Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT





DIXIE STATE COLLEGE SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE OF UTAH 225 S. 700 E. ST. GEORGE, UT 84770

MARK DATE DESCRIPTION

DATE: 10 JANUARY 2008

PROJECT NO: 06163660

HFSA PROJECT NO: 0647.01

CAD DWG FILE NO:

DRAWN BY: STAFF

CHECKED BY: SW

DESIGNED BY: WP

DWG TYPE: MECHANICAL

ARCHITECTURAL PHASE:
CONSTRUCTION DOCUMENTS

SHEET TITLE


SECOND FLOOR PLUMBING PLAN

PE102 et 5 OF 10


SECOND FLOOR PLUMBING PLAN


SCALE: 1/8" = 1'-0"






INTERIORS







(1) 3/4"Ø WATER ROUTED UNDER EXISTING COUNTER. SEE SECTION D5 THIS SHEET.

- 3/4"Ø AIR ROUTED UNDER EXISTING COUNTER. LOCATE ABOVE GAS PIPING. SEE
- $\sqrt{3}$ 3/4"Ø GAS ROUTED UNDER EXISTING COUNTER. LOCATE BELOW AIR PIPING. SEE SECTION D5 THIS SHEET.
- $\langle 4 \rangle$ DRILL THROUGH EXISTING COUNTER TOP. PROVIDE COUNTER MOUNTED TURRETS AND SERRATED VALVES FOR WATER, GAS, AND COMPRESSED AIR.
- EXISTING WATER PROJECTION ABOVE TOP OF CABINET. PROVIDE NEW VACUUM BREAKER AND PROVIDE NEW PIPING BACK TO UNDER COUNTER. SEE DETAIL

SHEET NOTES:

- CONNECT TO EXISTING AIR AND GAS PIPING UNDER COUNTER. PLUG HOLES IN COUNTER TOP WHERE EXISTING PIPING IS REMOVED.
- $\langle 7 \rangle$ EXISTING SINKS.
- (8) EXISTING WORK COUNTERTOP.
- (9) DRAWERS.
- (10) OPEN CLOSET IN CABINET.
- (11) LEG SPACE UNDER CABINET.

SUPPLY AIR (HEATING AND COOLING)

FROM TRENCH UNDER FLOOR.

FLEX CONNECTOR

BLOWER ACCESS PANELS ON TOP BOTTOM

DUCT WRAP

AND BOTH SIDES

BLOWER SECTION

RE-HEAT COIL SECTION

RETURN AIR INLET SOUND

CEILING PLENUM FOR USE

WHEN PRIMARY FAN IS OFF.

ATTENUATOR - OPEN TO

HWS AND HWR FROM PIPING IN TUNNEL UNDER FLOOR

BALL VALVE TYP.

BLOW DOWN VALVE.

STRAINER W/

AUTO TWO WAY


VALVE FURNISHED

AND INSTALLED BY


MECHANICAL

CONTRACTOR

BY ATC CONTRACTOR



TYPICAL TABLE TOP PIPING PLAN VIEW FOR CHEMISTRY LAB 204 SCALE: 1/2" = 1'-0"



RETURN AIR BOOT DETAIL

VENTURI BALANCING VALVE

HIGH POINT VENT CONSISTING -

OF TEE, BALL VALVE AND VENT

THERMOMETER

PRESSURE GAUGE W/ ____

DRAIN VALVE CONSISTING OF TEE, BALL VALVE WITH

HOSE END. (TYP.)

SUPPORT FROM STRUCTURE.

SERVICE ACCESS AT BOX.

LOCATE HANGERS TO MAINTAIN

(TYPICAL) SEE SPECIFICATIONS

GAUGE COCK AND SNUBBER

NOTE:

PROVIDE DRAIN PAN UNDER

ALL BOXES, ROUTE DRAIN

PIPING TO NEAREST DRAIN.

FAN POWERED BOX

(W/ RE-HEAT COIL) DETAIL

(TYP.)

SCALE: NONE


| | | SSURE ROI | | | | | |
|-----------------------|----------------------|----------------------------|------------------------------------|----------------------------|--|--|--|
| DUCT | | M 2" W.G. POSITIVE | MAXIMUM 2" W.G. STATIC NEGATIVE | | | | |
| DIAMETER IN INCHES | SPIRAL SEAM GAUGE | LONGITUDINAL SEAM GAUGE | SPIRAL SEAM GAUGE | LONGITUDINAL SEAM GAUGE | | | |
| 3 thru 8 | 28 | 28 | 28 | 24 | | | |
| 9 thru 14 | 28 | 26 | 26 | 24 | | | |
| 15 thru 26 | 26 | 24 | 24 | 22 | | | |
| 27 thru 36 | 24 | 22 | 22 | 20 | | | |
| 37 thru 50 | 22 | 20 | 20 | 18 | | | |
| | | | | | | | |

LOW PRESSURE ROUND **DUCT CONSTRUCTION DETAIL** (C3)SCALE: NONE

| HWS AND HWR FROM PIPING | | | | | | | | |
|--|---|--|---|-------------------|--|---|---|--------------------------|
| IN TUNNEL UNDER FLOOR LOCATED IN NEW CHASE. BALL VALVE STRAINER W/ BLOW DOWN VALVE. AUTO THREE WAY VALVE FURNISHED BY ATC CONTRACTOR AND INSTALLED BY MECHANICAL CONTRACTOR. | DIMENSION OF LONGEST SIDE, INCHES | SHEET METAL GAGE (ALL FOUR SIDES) | MINIMUM REINFORCING ANGLE SIZE AND MAXIMUM LONGITUDINAL SPACING BETWEEN TRANSVERSE JOINTS &/OR INTERMEDIATE REINFORCING | MIN. H. IN. | DRIVE SLIP PLAIN S SLIP RECOM- MENDED GAGE | HEMMED S SLIP RECOM- MENDED GAGE | INTS ALTER'NT BAR SLIP RECOM- MENDED GAGE | RECOM- MENDED GAGE |
| | UP THRU 12 | 26 | NONE REQUIRED | 1 | 26 | 26 | 24 | 24 |
| COIL CONNECTION | 13 - 18 | 24 | NONE REQUIRED | 1 | 24 | 24 | 24 | 24 |
| | 19 - 30 | 24 | 1"X1"X1/8" @ 60 IN | 1 | - | 24 | 24 | 24 |
| | 31 - 36 | 22 | 1"X1"X1/8" @ 60 IN | 1 | - | - | 22 | 22 |

1. TRANSVERSE REINFORCING SIZE IS DETERMINED BY DIMENSION OF SIDE TO WHICH ANGLE IS APPLIED.

DUCT CONSTRUCTION DETAIL




GAS LINE CONNECTION DETAIL

SHEET NOTES:


- (1) EXISTING LAB TABLES.
- NEW 3/4" COLD WATER ROUTED IN VOID SPACE BETWEEN COUNTERS. SOURCE OF WATER SHALL BE THE SAME AS EXISTING, ORIGINATING UNDER THE NORTH
- NEW 3/4" GAS PIPING, ROUTED IN VOID SPACE BETWEEN COUNTERS. SOURCE OF GAS PIPING SHALL BE THE SAME AS EXISTING, ORIGINATING UNDER THE NORTH
- NEW 3/4" COMPRESSED AIR PIPING, ROUTED IN VOID SPACE BETWEEN COUNTERS. SOURCE OF AIR PIPING SHALL BE THE SAME AS EXISTING, ORIGINATING UNDER THE NORTH SINK.
- $\overline{\langle 5
 angle}$ NEW AIR, GAS AND WATER TURRETS. INSTALLED ON TOP OF EXISTING COUNTER TOPS. SEE PLAN VIEW THIS SHEET FOR LOCATIONS AND QUANTITY.
- (6) DRILL HOLES IN EXISTING COUNTER TOPS.
- $\langle 7 \rangle$ ROUTE PIPING IN BACK OF EVERY CABINET ON BOTH SIDES. SEE PLAN VIEW THIS SHEET. KEEP AS FAR BACK AS POSSIBLE
- $\langle 8 \rangle$ EXISTING CENTER SUPPORTS
- \langle 9 angle EXISTING 6" WIDE CENTER TROUGH.
- (10) EXISTING COUNTER TOPS SHALL REMAIN.

ROOM 204 PIPING SECTION SCALE: NONE


LOOKING NORTH



ROOF MOUNTED EXHAUST FAN DETAIL




ROOF PIPING SUPPORT DETAIL SCALE: NONE



OF NEW WALL

CADAVER AREA EXHAUST DETAIL SCALE: NONE

LOCATIONS.



HFSArchitects

CONSULTANT


ARCHITECTURE **INTERIORS P**LANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693

www.hfsa.com







DIXIE STATE COLLEGE SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE OF UTAH 225 S. 700 E. ST. GEORGE, UT 84770

DATE DESCRIPTION

10 JANUARY 2008 PROJECT NO: 06163660 HFSA PROJECT NO: 0647.01 CAD DWG FILE NO: DRAWN BY: STAFF CHECKED BY: **DESIGNED BY**

DWG TYPE: MECHANICAL ARCHITECTURAL PHASE: CONSTRUCTION DOCUMENTS SHEET TITLE

MECHANICAL AND PLUMBING DETAILS

MP501

SHEET

of 10

| | EXHAUST FAN SCHEDULE | | | | | | | | | | | | | | |
|---------|--------------------------|-------------|--------|----------|--------------------|------------|-------|------|--------------------|----------|-------------------|--|--|--|--|
| SYMBOL | MANUFACTURER & MODEL No. | SERVES | C.F.M. | PRESSURE | MAX NOISE SONES | | MOTOR | | OPER. WT. (LBS) | COMMENTS | SCHEDULE NOTES | | | | |
| | WIODEL NO. | | | IN. WG. | CONES | V - Ø - Hz | HP | RPM | (250) | | NOTES | | | | |
| EF 1 | COOK 195 ACEB | CADAVER LAB | 3200 | .25 | 9.5 | 115/1/60 | 1/2 | 1725 | 150 | | | | | | |
| | | | | | | | | | | | | | | | |

| OMMENTS | SCHEDULE NOTES | grin. |
|---------|-------------------|-------|
| | | E |


HFSArchitects

INTERIORS **P**LANNING

1484 South State Street Salt Lake City, Utah 84115 801-596-0691/F: 596-0693

CONSULTANT





DIXIE STATE COLLEGE SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE OF UTAH 225 S. 700 E. ST. GEORGE, UT 84770

| | MAKE-UP AIR UNIT SCHEDULE | | | | | | | | | | | | | | | | | |
|---------|---------------------------|-------------------|--------------|----------------------|----------------------|--------------|---------|------|-----|-----------------|---|----|-------|--------------------------|-----|-------------|-------------------------|------------------------------|
| | | | | HEATING | | | COOLING | | | | | | EL | ECTRICAL | | | | |
| SYMBOL | CFM | E.S.P. IN W.G. | MBH INPUT | ENT. AIR TEMP. | AIR TEMP. RISE | MBH TOTAL | EADB | EAWB | LDB | EVAP. FAN HP | Ø | Hz | VOLTS | COMPRESSOR RLA (EACH) | MCA | MAX FUSE | UNIT WEIGHTS IN LBS. | MANUFACTURER MODEL NUMBER |
| MA 1 | 2880 | 1.2 | 244 | 19 | 71 | 171 | 110 | 71 | 55 | 5 | 3 | 60 | 208 | 22.4 | 78 | 100 | 1900 | AAON RM-015 1 2 3 |

- 1 PROVIDE WITH MODULATING GAS VALVE.
- 2 PROVIDE WITH HOT GAS BY-PASS.
- (3) PROVIDE WITH DUAL MINIMUM POSITION ECONOMIZER.

| | FAN POWERED VAV BOX SCHEDULE | | | | | | | | | | | | | | | |
|----------|------------------------------|------------------------|--------------------|---------------------------------------|---------|----------|----------|-----------|----------|----------|--------|--------------------|----------|--------------------|----------------|-------|
| SYMBOL | SERVES | INLET DIA. (INCHES) | OUTLET (INCHES) | PRIMARY AIRFLOW HEATING (40° DELTA T) | | | | | | NC LEVEL | ELECT. | MANUF. & MODEL# | SCHEDULE | | | |
| | | | (11401120) | MAX CFM | MIN CFM | COIL EAT | COIL LAT | COIL BTUH | FLOW GPM | EWT | ROWS | (FT) PD | | | WODEL# | NOTES |
| FPB 1 | BIOLOGY LAB 127 | 14 | 20x18 | 1700 | 450 | 70 | 110 | 66000 | 6 | 180 | 2 | 4.84 | 31 | 1/2 HP 115/1/60 | PRICE FDCQ2 | 1,2,3 |
| FPB 2 | MICRO-BIOLOGY LAB 129 | 14 | 20x18 | 1700 | 450 | 70 | 110 | 66000 | 6 | 180 | 2 | 4.84 | 31 | 1/2 HP 115/1/60 | PRICE FDCQ2 | 1,2,3 |
| FPB 3 | BIO TECH LAB 136 | 14 | 20x18 | 1700 | 450 | 70 | 110 | 66000 | 6 | 180 | 2 | 4.84 | 31 | 1/2 HP 115/1/60 | PRICE FDCQ2 | 1,2,3 |
| FPB 4 | COMPUTER LAB 117 | 14 | 20x18 | 1700 | 450 | 70 | 110 | 66000 | 6 | 180 | 2 | 4.84 | 31 | 1/2 HP 115/1/60 | PRICE FDCQ2 | 1,2,3 |

1. PROVIDE WITH INLET AND OUTLET SOUND ATTENUATORS.

2. PROVIDE WITH ECM MOTORS. 3. FAN POWERED BOXES SHALL BE DESIGNED FOR SERIES FLOW WITH A MINIMUM 0.25" DISCHARGE SP. 4. NC IS RATED DISCHARGE NC AT 0.5" DELTA P.

| REGISTER, LOUVER & GRILLE SCHEDULE |
|------------------------------------|
| |

| | SYMBOL | TYPE | SERVICE | MAX CFM | NOMINAL SIZE | THROAT SIZE | CEILING TYPE | SCHEDULE NOTES |
|---|--------|-----------|---------|--------------------------|-----------------|----------------|----------------------|-------------------|
| | R-1 | CEILING | RETURN | 600 | 16/16 | 16/16 | LAY-IN | 1,2,3,4 |
| , | R-2 | TOE SPACE | RETURN | 1700 CFM 105 CFM/L.F. | 3"-17' | OPEN | CABINET TOE SPACE | 1,3,5,6 |
| | EG-1 | SIDEWALL | EXHAUST | 800 | 24/14 | 24/14 | NA | 1,2,3,4 |

REGISTER. LOUVER AND DIFFUSER SCHEDULE NOTES:

- 1. MAXIMUM NC = 25 @ MAXIMUM CFM NOTED.
- 2. SHALL BE PRICE 535 OR EQUAL BY APPROVED MANUFACTURER IN SPECIFICATIONS.
- 3. SEE SPECIFICATIONS FOR APPROVED MANUFACTURERS.
- 4. FINISH SHALL BE STANDARD WHITE.
- 5. ALUMINUM FINISH FOR TOE SPACE GRILLES.
- 6. SHALL BE PRICE LBP/15 B WITH 1/2" BORDER.

| | DIFFUSER SCHEDULE | | | | | | | | | | | | | |
|------------|-------------------|---------|-----------|----------|-----------------|------|------------|-------------------|--|--|--|--|--|--|
| SYMBOL | TYPE | MAX CFM | FACE SIZE | NCK SIZE | CEILING TYPE | BLOW | PATTERN | SCHEDULE NOTES | | | | | | |
| D-1 CFM | CEILING | 500 | 12X12 | 12"Ø | LAY-IN | 4WAY | 4 ♥ | 1,2,3,4,5 | | | | | | |
| D-2 CFM | CEILING | 750 | 15X15 | 14"Ø | LAY-IN | 4WAY | ▲ ▶ | 1,2,3,4,5 | | | | | | |

- 1. PROVIDE LAY-IN CEILING AND BORDER / MODULE AS REQUIRED. SEE ARCHITECTURAL CEILING PLANS.
- 2. MAXIMUM NC 25 AT CFM LISTED.
- 3. PROVIDE TRANSITION TO DIFFUSER NECK SIZE AS REQUIRED TO DUCT WORK SHOWN ON PLAN.
- 4. DIFFUSER SHALL BE PRICE MODEL SMD OR EQUAL BY APPROVED MANUFACTURER IN SPECIFICATIONS.
- 5. FINISH SHALL BE STANDARD WHITE.

NEUTRALIZATION TANK SCHEDULE

| SYMBOL | VOLUME GAL. | LENGTH | DIAMETER | WEIGHT LBS | INLET" OUTLET" VENT " | SCHEDULE NOTES |
|---------|-------------|--------|----------|------------|-----------------------------|-------------------|
| NT 1 | 5 | 16.25" | 11" | 9 LBS | 2" 2" 2" SIDE | 1,2 |

1. ORION STYLE 7

2. FOR OTHER APPROVED MANUFACTURER'S SEE SPECIFICATIONS.

| | | PLUM | BING F | IXTUR | E SCH | EDULE | |
|-------------|--------------------|-----------|--------------|----------|--------------|----------|-----------------|
| SYMBOL | FIXTURE | | INDIV | | REMARKS | | |
| | | TRAP | WASTE | VENT | HOT WATER | | |
| S-1 | SINK | 2" | 2" | 1-1/2" | 1/2" | 1/2" | SINK BY OTHERS. |
| * PROVIDE N | EW FAUCETS FOR ALL | NEW SINKS | . SEE SPECIF | ICATIONS | 1 | <u> </u> | |

MARK DATE DESCRIPTION

10 JANUARY 2008 PROJECT NO: 06163660 HFSA PROJECT NO: 0647.01 CAD DWG FILE NO: STAFF DESIGNED BY:

MECHANICAL ARCHITECTURAL PHASE:
CONSTRUCTION DOCUMENTS

MECHANICAL AND PLUMBING SCHEDULES

MP601

KEYED NOTES: REMOVE EXISTING 4 FT, 2 LAMP SURFACE MOUNTED FLOURESCENT FIXTURE FROM EXISTING CEILING TO BE REMOVED INCLUDING ALL ABANDONED WIRING, CONDUIT, BOXES, ETC... NOTE 4 LAMP FIXTURES IN ROOMS IIT AND 135.

 $\langle 2 \rangle$ REMOVE EXISTING EXIT LIGHT FROM EXISTING CEILING TO BE REMOVED. INCLUDING ALL ABANDONED WIRING, CONDUIT, BOXES, ETC...

(3) REMOVE EXISTING RECESSED INCANDESCENT FIXTURE FROM EXISTING CEILING TO BE REMOVED INCLUDING ALL ABANDONED WIRING, CONDUIT, BOXES, ETC... (4) REMOVE EXISTING SWITCH FROM EXISTING WALL TO BE REMOVED INCLUDING ALL

ABANDONED WIRING, CONDUIT, BOXES, ETC... (5) REMOVE EXISTING SWITCH AND WIRING. ABANDON EXISTING OUTLET BOX IN EXISTING MASONRY WALL TO REMAIN TO BE COVERED BY NEW WALL FURRING

WITH ALL WIRING REMOVED. (6) REMOVE EXISTING SURFACE MOUNTED LIGHT TRACK AND FIXTURES FROM EXISTING CEILING TO BE REMOVED INCLUDING ALL ABANDONED WIRING, CONDUIT,

 \langle 1 \rangle REMOVE EXISTING SWITCH AND WIRING. PROVIDE BLANK COVERPLATE ON EXISTING OUTLET BOX.

BOXES, ETC...

υάποποπουρί

 $\langle 1 \rangle$ TYPICAL $\overline{\ }$ G-23 $\overline{\ }$

CORR 100F

EMA-3 EMA-9

CLASSROOM/LAB

D-8,10,12-

extstyle ext

OFFICE 119

OFFICE 121

OFFICE 123

WORKROOM 118A

τότοιοιοίοιοιο

- TYPICAL -

CLASSROOM

OFFICE

:=<u>क</u>्===<u>क</u>==

 $\langle 8 \rangle$ REMOVE EXISTING 4 FT, 4 LAMP SURFACE MOUNTED FLOURESCENT FIXTURE. EXISTING OUTLET BOX AND CIRCUIT TO REMAIN FOR INSTALLATION OF NEW FIXTURE SHOWN ON SHEET ELIØI. CLEAN EXISTING CEILING PRIOR TO INSTALLATION OF NEW FIXTURES.

 \langle 1 angleTYPICAL -

CLASSROOM

-(1) TYPICAL -

| CORR

4—D-4,6

(9) REMOVE EXISTING 4 FT, I LAMP WALL MOUNTED FLOURESCENT FIXTURE. EXISTING OUTLET BOX AND CIRCUIT TO REMAIN FOR INSTALLATION OF NEW FIXTURE SHOWN ON SHEET ELIØI. CLEAN EXISTING WALL PRIOR TO INSTALLATION OF NEW FIXTURES.

STORAGE F

KEYED NOTES:

 \langle IØangle REMOVE EXISTING 4 FT, 2 LAMP SURFACE MOUNTED FLOURESCENT FIXTURE AND EXISTING RECESSED INCANDESCENT FIXTURE. PROVIDE NEW OUTLET BOX IN EXISTING CEILING FOR INSTALLATION OF NEW FIXTURE SHOWN ON SHEET ELIØI. REPAIR EXISTING CEILING AS REQUIRED TO MATCH SURROUNDING SURFACES.

(II) REMOVE EXISTING RECESSED INCANDESCENT FIXTURE INCLUDING ABANDONED WIRING, CONDUIT, BOXES, ETC... REPAIR EXISTING CEILING AS REQUIRED TO MATCH SURROUNDING SURFACES.

 $\langle r \rangle$ REMOVE EXISTING 4 FT, I LAMP SURFACE MOUNTED FLOURESCENT FIXTURE. EXISTING OUTLET BOX AND CIRCUIT TO REMAIN FOR INSTALLATION OF NEW FIXTURE SHOWN ON SHEET ELIØI. CLEAN EXISTING CEILING PRIOR TO INSTALLATION OF NEW FIXTURES.

3) REMOVE EXISTING RECESSED INCANDESCENT FIXTURE INCLUDING, ABANDONED WIRING, CONDUIT, BOXES, ETC... PROVIDE NEW OUTLET BOX IN EXISTING CEILING FOR INSTALLATION OF NEW FIXTURE SHOWN ON SHEET ELIØI. REPAIR EXISTING CEILING AS REQUIRED TO MATCH SURROUNDING SURFACES.

(14) REMOVE EXISTING RECESSED INCANDESCENT FIXTURE FROM EXISTING CEILING TO REMAIN. RETAIN EXISTING BRANCH CIRCUIT FOR CONNECTION TO NEW FIXTURE SHOWN ON SHEET ELIØ1.

(15) REMOVE EXISTING FIXTURES TO ALLOW INSTALLATION OF NEW WALLS. REMOVE ABANDONED WIRING, CONDUIT, BOXES, ETC... RETAIN EXISTING CIRCUIT FOR CONNECTION TO NEW FIXTURES SHOWN ON SHEET ELØI.

 $-\!\!\langle$ $_{1}\rangle$ typical -

1 TYPICAL —

CLASSROOM/LAB

VESTIBULE

r---G-17

[] +-- G-15,17

 \langle 16angle REMOVE EXISTING BATTERY EMERGENCY LIGHTING UNIT AND CONNECTION TO EXISTING WALL MOUNTED FLUORESCENT FIXTURE. REPAIR AND CLEAN EXISTING WALL AS REQUIRED TO MATCH SURROUNDING SURFACES.

GENERAL NOTES:

MEN 110B

WOMEN 110A

OF THE WORK.

1. LOCATIONS OF EXISTING ELECTRICAL EQUIPMENT, LIGHTING, SWITCHES, OUTLETS, BRANCH CIRCUIT WIRING, ETC., ARE BASED ON EXISTING BUILDING ELECTRICAL DRAWINGS AND FIELD OBSERVATION OF EXISTING SURFACE CONDITIONS. FIELD VERIFY EXISTING LOCATIONS AND CIRCUITING AND IMMEDIATELY NOTIFY THE ARCHITECT OF ANY DISCREPANCIES WHICH MAY ADVERSELY AFFECT COMPLETION

LECTURE HALL

2. DEMOLITION PLAN IS SHOWN FOR CONTRACTORS REFERENCE ONLY. FIELD VERIFY QUANTITIES AND LOCATIONS OF ALL EXISTING MATERIAL AND EQUIPMENT TO BE REMOVED. REMOVE ALL ABANDONED WIRING, CONDUIT, BOXES, OUTLETS, FIXTURES, EQUIPMENT, ETC., WHETHER SPECIFICALLY SHOWN OR NOT.

3. REMOVE ALL EXISTING FIXTURES, OUTLETS, SWITCHES, ETC., SHOWN ON THE DEMOLITON PLAN, EXCEPT WHERE SPECIFICALLY NOTED TO REMAIN OR BE

4. CONTRACTOR MAY USE EXISTING BRANCH CIRCUIT WIRING AND RACEWAYS WHERE CONVENIENT TO CONNECT TO NEW ELECTRICAL DEVICES ONLY IF THE EXISTING WIRING AND RACEWAYS ARE IN GOOD CONDITION AND MEET DIVISION 16 SPECIFICATION REQUIREMENTS FOR NEW WIRING AND RACEWAYS.

5. WHERE REMOVAL OF EXISTING ELECTRICAL EQUIPMENT INTERRUPTS EXISTING BRANCH CIRCUITS OR FEEDERS TO EXISTING EQUIPMENT TO REMAIN, PROVIDE NEW CONDUIT AND WIRING AS REQUIRED TO RECONNECT THE EXISTING EQUIPMENT.

GENERAL NOTES:

PHYSICS CLASSROOM


PHYSICS LECTURE

CONFERENCE
108

OFFICE

6. ALL MATERIALS AND EQUIPMENT REMOVED SHALL REMAIN THE PROPERTY OF THE OWNER AND SHALL BE TURNED OVER TO THE OWNER FOR STORAGE OR BE DISPOSED OF BY THE CONTRACTOR AS DIRECTED BY THE OWNER.

1. TAKE ALL PRECAUTIONS NECESSARY TO AVOID DAMAGE TO THE EXISTING BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE GENERAL CONTRACTOR.



HFSArchitects

NTERIORS **P**LANNING 1484 South State Salt Lake City, Utah 84115

801-596-0691/F: 596-0693

www.hfsa.com

ARCHITECTURE

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

DESCRIPTION

30 JANUARY 2008

0730 E-101.dwg


ELECTRICAL

OF 9 (ELECT.)

07043640

0730.01

W.B.G.



A3 1ST FLOOR LIGHTING DEMOLITION PLAN

SCALE: 1/8" = 1'-0" 3



KEYED NOTES: KEYED

STORAGE 115A

- (1) EXISTING CEILING MOUNTED PROJECTOR AND ASSOCIATED CABLES TO BE REMOVED BY OWNER PRIOR TO BEGINNING OF DEMOLITION.
- 2 REMOVE EXISTING CEILING RECEPTACLE AND SURFACE RACEWAY FOR EXISTING CEILING PROJECTOR.
- (3) REMOVE SURFACE RACEWAY FOR EXISTING CEILING PROJECTOR.
- 4 REMOVE EXISTING RECEPTACLES AND ALL WIRING. ABANDON EMPTY OUTLET BOXES IN PLACE TO BE COVERED BY NEW CABINETS. PROVIDE BLANK COVERPLATE FOR OUTLET BOXES NOT CONCEALED BY CABINETS. EXTEND OUTLET BOX INTO BACK OF CABINET AND PROVIDE BLANK COVERPLATE IF EXISTING WIRING CANNOT BE COMPLETELY REMOVED.
- (5) REMOVE EXISTING RECEPTACLE AND SURFACE RACEWAY EXTENSION BOX.
 PROVIDE NEW RECEPTACLE AND COVERPLATE, AND NEW BRANCH CIRCUIT HOMERUN AS SHOWN ON SHEET EPIØI.
- (6) REMOVE EXISTING JUNCTION BOX INCLUDING CONDUITS INTO TUNNEL BELOW.
 SEAL EXISTING CONDUIT PENETRATIONS INTO FLOOR.
- TEMOVE EXISTING EXISTING FLOOR OUTLET RECEPTACLE, COVER, AND ALL WIRING. PROVIDE NEW BLANK COVER FOR EXISTING FLOOR OUTLET BOX. REMOVE FLOOR BOX WHERE REQUIRED TO SAWCUT EXISTING FLOOR FOR INSTALLATION OF NEW UNDERFLOOR UTILITIES.
- (8) EXISTING RECEPTACLE TO REMAIN, SHOWN CIRCUITING REFERENCE ONLY.
 RECONNECT CIRCUIT AS SHOWN ON SHEET EPIØI.

16

CORR 100E

GREENHOUSE

CORR 100H

OFFICE

OFFICE

OFFICE

OFFICE

OFFICE

IC-1,3,5

CORR 100F

TYPICAL

OFFICE

OFFICE

OFFICE

MEN 140

\-1C-3,5

KEYED NOTES:

- 9 REMOVE ABANDONED SLIDE PROJECTOR CONTROL RECEPTACLE AND CABLE.
 REMOVE ALL ACCESSIBLE CONDUIT, BOXES, ETC... UNDERFLOOR CONDUIT MAY
 BE ABANDONED IN PLACE.
- REMOVE EXISTING SURFACE MOUNTED DATA OUTLET INCLUDING SURFACE RACEWAY SYSTEM AND DATA CABLES COMPLETE TO POINT OF ORIGINATION.
- (11) REMOVE EXISTING RECEPTACLE FROM EXISTING WALL TO BE REMOVED INLCUDING ABANDONED WIRING, CONDUIT, BOXES, ETC...
- AND SURFACE TELE/DATA OUTLETS FROM EXISTING WALL TO REMAIN. REPAIR EXISTING WALL AS REQUIRED FOR NEW FINISHES.

 (13) REMOVE EXISTING SURFACE RECEPTACLE FROM INTERIOR OF EXISTING
- (13) REMOVE EXISTING SURFACE RECEPTACLE FROM INTERIOR OF EXISTING AUDIO-VISUAL CABINET TO BE REMOVED. REMOVE ALL ABANDONED WIRING, CONDUIT, BOXES, ETC..
- REMOVE ELECTRICAL CIRCUIT TO EXISTING ROOF MOUNTED EXHAUST FAN TO BE REMOVED. REMOVE ALL ABANDONED WIRING, CONDUIT, BOXES, ETC...

 $\langle 12
angle$ REMOVE EXISTING SURFACE MULTI-OUTLET ASSEMBLIES, SURFACE RECEPTACLES,

- (15) REMOVE EXISTING RECEPTACLE AND WIRING. ABANDON EXISTING OUTLET BOX IN EXISTING MASONRY WALL TO REMAIN TO BE COVERED BY NEW WALL FURRING WITH ALL WIRING REMOVED.
- DISCONNECT AND RECONNECT EXISTING ELECTRICAL AND COMMUNICATION CONNECTIONS TO EXISTING TEACHING STATION CABINETS AS REQUIRED TO ALLOW REMOVAL AND REINSTALLATION OF THE CABINETS.

VESTIBULE

GENERAL NOTES:

MEN 110B

> WOMEN 110A

> > STAIR 100B

- 1. LOCATIONS OF EXISTING ELECTRICAL EQUIPMENT, LIGHTING, SWITCHES, OUTLETS, BRANCH CIRCUIT WIRING, ETC., ARE BASED ON EXISTING BUILDING ELECTRICAL DRAWINGS AND FIELD OBSERVATION OF EXISTING SURFACE CONDITIONS. FIELD VERIFY EXISTING LOCATIONS AND CIRCUITING AND IMMEDIATELY NOTIFY THE ARCHITECT OF ANY DISCREPANCIES WHICH MAY ADVERSELY AFFECT COMPLETION OF THE WORK.
- DEMOLITION PLAN IS SHOWN FOR CONTRACTORS REFERENCE ONLY. FIELD VERIFY QUANTITIES AND LOCATIONS OF ALL EXISTING MATERIAL AND EQUIPMENT TO BE REMOVED. REMOVE ALL ABANDONED WIRING, CONDUIT, BOXES, OUTLETS, FIXTURES, EQUIPMENT, ETC., WHETHER SPECIFICALLY SHOWN OR NOT.
- 3. REMOVE ALL EXISTING FIXTURES, OUTLETS, SWITCHES, ETC., SHOWN ON THE DEMOLITON PLAN, EXCEPT WHERE SPECIFICALLY NOTED TO REMAIN OR BE
- 4. CONTRACTOR MAY USE EXISTING BRANCH CIRCUIT WIRING AND RACEWAYS WHERE CONVENIENT TO CONNECT TO NEW ELECTRICAL DEVICES ONLY IF THE EXISTING WIRING AND RACEWAYS ARE IN GOOD CONDITION AND MEET DIVISION 16 SPECIFICATION REQUIREMENTS FOR NEW WIRING AND RACEWAYS.
- IN 5. WHERE REMOVAL OF EXISTING ELECTRICAL EQUIPMENT INTERRUPTS EXISTING BRANCH CIRCUITS OR FEEDERS TO EXISTING EQUIPMENT TO REMAIN, PROVIDE NEW CONDUIT AND WIRING AS REQUIRED TO RECONNECT THE EXISTING EQUIPMENT.

LECTURE HALL

GENERAL NOTES:

PHYSICS CLASSROOM


ASTRONOMY LAB

PHYSICS LECTURE

CONFERENCE

HALLWAY 101A

- 6. ALL MATERIALS AND EQUIPMENT REMOVED SHALL REMAIN THE PROPERTY OF THE OWNER AND SHALL BE TURNED OVER TO THE OWNER FOR STORAGE OR BE DISPOSED OF BY THE CONTRACTOR AS DIRECTED BY THE OWNER.
- 1. TAKE ALL PRECAUTIONS NECESSARY TO AVOID DAMAGE TO THE EXISTING BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE GENERAL CONTRACTOR.



HFSArchitects

ARCHITECTURE
INTERIORS
PLANNING

1484 South State Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

| В | | | |
|---|--------------------|-------------|----------------------|
| | | T | |
| | MARK | DATE | DESCRIPTION |
| | | | |
| | | | |
| | | | |
| | | | |
| | DATE: | | 30 JANUARY 2008 |
| | | PROJECT NO: | 07043640 0730.01 |
| | CAD DW | G FILE NO: | 0730 E-101.dwg |
| | DRAWN I | | W.B.G. R.G.K. |
| | DESIGNE DWG TYF | | W.B.G. ELECTRICAL |
| | | CTURAL PHAS | SE: |
| | SHEET T | | UCTION DOCUMENTS |
| Α | | | FLOOR |
| | | 101 | FLOOR |
| | | | |
| | | PC | OWER |

ED102

2 OF 9 (ELECT.)





VESTIBULE

KEYED NOTES:

- REPLACE EXISTING FIXTURES WITH NEW FIXTURES INDICATED AND CONNECT TO EXISTING CIRCUIT AND SWITCHES UNLESS NOTED OTHERWISE. EXISTING CIRCUIT IS SHOWN FOR REFERENCE.
- 2 PROVIDE NEW FLUORESCENT FIXTURE TO REPLACE EXISTING INCANDESCENT FIXTURE. CHAIN MOUNT NEW FIXTURE AS REQUIRED TO CLEAR EXISTING PIPING, DUCTWORK, ETC., AND CONNECT TO EXISTING FIXTURE OUTLET BOX WITH FLEXIBLE STEEL CONDUIT. FIELD VERIFY EXISTING CIRCUITING.
- (3) NEW 6" WIDE x 2" DEEP WIRE TYPE CABLE TRAY IN EXISTING TUNNEL. COORDINATE EXACT LOCATION WITH EXISTING PIPING TO PROVIDE MINIMUM 12" CLEARANCE FROM EXISTING HOT WATER PIPING.
- 4 PROVIDE 2" CONDUIT THROUGH TUNNEL WALL FOR DATA CABLES AND SEAL CONDUIT PENETRATION AIRTIGHT.
- 5 NEW 6" WIDE x 2" DEEP WIRE TYPE CABLE TRAY THROUGH MECHANICAL ROOM.
 COORDINATE EXACT LOCATION WITH EXISTING EQUIPMENT AND PIPING.
- (6) PROVIDE (2) 4" CONDUIT SLEEVES THROUGH EXISTING CEILING TO EXISTING TELE/DATA TERMINAL BOARD ON MAIN FLOOR ABOVE. CORE-DRILL AND FIRE SEAL EXISTING CONCRETE FLOOR TO INSTALL NEW CONDUITS.


GENERAL NOTES:

ALTERNATE NO. 1.

- COORDINATE FIXTURE LOCATIONS WITH ARCHITECT'S REFLECTED CEILING PLAN,
 CEILING CONTRACTOR, BUILDING STRUCTURE, MECHANICAL EQUIPMENT & DUCTWORK LOCATIONS, ETC.
- 2. WHERE BRANCH CIRCUIT HOMERUNS INDICATE WIRE SIZES, USE THAT SIZE WIRE G, THROUGHOUT THE BRANCH CIRCUIT, INCLUDING SWITCH LEGS, ETC.
- 3. TAKE ALL PRECAUTIONS NECESSARY TO AVOID DAMAGE TO THE EXISTING BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE GENERAL CONTRACTOR.

ADDITIVE ALTERNATE NO. 1 - DATA CABLES:

1. PROVIDE NEW PLENUM RATED CATEGORY 5E DATA CABLES FROM EACH NEW DATA OUTLET TO EXISTING TELEPHONE/DATA TERMINALS UNDER ADDITIVE



HFSArchitects

ARCHITECTURE
INTERIORS
PLANNING

1484 South State Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT


ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South
Salt Lake City, Utah 84115
801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE


ST. GEORGE, UTAH




BASEMENT ELECTRICAL PLAN

E-101

HEET 3 OF 9 (ELECT.)






1. COORDINATE FIXTURE LOCATIONS WITH ARCHITECT'S REFLECTED CEILING PLAN, CEILING CONTRACTOR, BUILDING STRUCTURE, MECHANICAL EQUIPMENT &

2. WHERE BRANCH CIRCUIT HOMERUNS INDICATE WIRE SIZES, USE THAT SIZE WIRE

THROUGHOUT THE BRANCH CIRCUIT, INCLUDING SWITCH LEGS, ETC.

BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE



HFSArchitects

ARCHITECTURE NTERIORS **P**LANNING 1484 South State

Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

| MARK | DATE | DESCRIPTION |
|-------|------|-----------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| DATE: | | 30 JANUARY 2008 |
| | | |

AGENCY PROJECT NO: 0730.01 HFSA PROJECT NO: 0730 E-101.dwg CAD DWG FILE NO: **DESIGNED BY:** W.B.G. DWG TYPE: ELECTRICAL

CONSTRUCTION DOCUMENTS SHEET TITLE

ARCHITECTURAL PHASE:

1ST FLOOR LIGHTING PLAN

EL101

| | | FIXTU | RE SCHEDULE | |
|------|---|--|---|-----------------------------|
| | MANUFACTURER | CATALOG NO. | DESCRIPTION | LAMP |
| F-1 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | WC4-232-EU CAN-232-UNV-1/2-EB10I WA4A-232-UNV-HI LB232-MVOLT-GEB10IS F9-232-A-SSO10-UE WS232A-UNV-EB81 | 4 FT, 2 LAMP SURFACE MOUNTED 'WRAPAROUND' FLUDRESCENT FIXTURE WITH ACRYLIC PRISMATIC LENS AND ONE 2 LAMP <10% THD ELECTRONIC BALLAST. | 2F32T8/ADV835/EW 30 WATT |
| F-2 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | WC8-232-EU TCAN-232-UNV-1/4-EB10I WA8A-232-UNV-HI TLB232-MVDLT-1/4-GEB10IS F9-232-2-A-SSD10-UE 8TWS232A-UNV-EB81 | 8 FT TANDEM, 2 LAMP ROW SURFACE MOUNTED 'WRAPAROUND' FLUORESCENT FIXTURE WITH ACRYLIC PRISMATIC LENS AND ONE 4 LAMP <10% THD ELECTRONIC BALLAST. | 4F32T8/ADV835/EW 30 WATT |
| F-3 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | RD8-132-EU TSJ-132-UNV-1/2-EB10I JS8C132-UNV-HI TCB-132-MVDLT-1/2-GEB10IS F12-132-2-A-SSD10-UE 8TCR-132A-UNV-EB81 | 8 FT TANDEM, 1 LAMP ROW SURFACE MOUNTED 'CORRIDOR' FLUORESCENT FIXTURE WITH ACRYLIC PRISMATIC LENS AND ONE 2 LAMP <10% THD ELECTRONIC BALLAST. | 2F32T8/ADV835/EW 30 WATT |
| F-4 | COLUMBIA DAY-BRITE LIGHTOLIER LSI METALUX PRUDENTIAL | WAL4-232-EU CD232-W-UNV-1/2-EB10I CWBU232-UNV-HI WB-232-SSD10-UE BI-232-UNV-EB81 P1850-2T804PRA-YGW-SC-UNV-10THD | 4 FT, 2 LAMP WALL MOUNTED FLUORESCENT FIXTURE WITH ACRYLIC PRISMATIC LENS AND ONE 2 LAMP <10% THD ELECTRONIC BALLAST. | 2F32T8/ADV835/EW 30 WATT |
| | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | 5PA24-232G-RAA12. 125-S-EU 2DPGS232-RA21-UNV-1/2-EB10I PRS2GRFVI232-UNV-HI 2SPGB-232RW-A12125-MVOLT-GEB10IS GN-A125-232-FD-SS010-UE 2GCB-RA-232-A125-UNV-EB81 | 2' x 4', 2 LAMP, LAY-IN FLUDRESCENT FIXTURE WITH REGRESSED FLOATING DOOR, BLACK REVEAL, 0.125" THICK ACRYLIC PRISMATIC LENS, AND ONE 2 LAMP <10% THD ELECTRONIC BALLAST. | |
| F-6 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | 5PA24-332G-RAA12. 125-S-EU 2DPGS332-RA21-UNV-2/12-EB10I PRS2GRFVI332-UNV-HI 2SPGB-332RW-A12125-MVOLT-GEB10IS GN-A125-332-FD-SS0102-UE 2GCB-RA-332-A125-UNV-EB82 | 2' x 4', 3 LAMP, LAY-IN FLUDRESCENT FIXTURE WITH REGRESSED FLOATING DOOR, BLACK REVEAL, 0.125" THICK ACRYLIC PRISMATIC LENS, AND ONE 1 LAMP AND ONE 2 LAMP <10% THD ELECTRONIC BALLASTS WIRED FOR INBOARD/OUTBOARD LAMP SWITCHING. | |
| F-7 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | 5PA24-432G-RAA12. 125-S-EU 2DPGS432-RA21-UNV-2/2-EB10I PRS2GRFVI432-UNV-HI 2SPGB-432RW-A12125-MVOLT-GEB10IS GN-A125-432-FD-SS0102-UE 2GCB-RA-432-A125-UNV-EB82 | 2' x 4', 4 LAMP, LAY-IN FLUDRESCENT FIXTURE WITH REGRESSED FLOATING DOOR, BLACK REVEAL, 0.125" THICK ACRYLIC PRISMATIC LENS, AND TWO 2 LAMP <10% THD ELECTRONIC BALLASTS WIRED FOR INBOARD/OUTBOARD LAMP SWITCHING. | |
| F-8 | DUAL-LITE EXITRONIX LIGHTOLIER LITHONIA MCPHILBEN SURE-LITES | SE-S-G-W G400U-LB-WW LD-A-1-G-W LE-S-W-1-G-120/277 30VL-1-W-G CX-6-1-G-W | UNIVERSAL MOUNTED, SINGLE FACE, LIGHT EMITTING DIODE (LED) EXIT LIGHT WITH DIE CAST ALUMINUM HOUSING, WHITE FINISH, GREEN LETTERS ON STENCIL FACE, UNIVERSAL KNOCKOUT CHEVRON ARROWS AND 120/277 DUAL VOLTAGE INPUT. | FURNISHED W/FIXTURE |
| F-9 | DUAL-LITE EXITRONIX LIGHTOLIER LITHONIA MCPHILBEN SURE-LITES | SE-D-G-W G400U-LB-WW LD-A-2-G-W LE-S-W-2-G-120/277 30VL-2-W-G CX-6-2-G-W | | FURNISHED W/FIXTURE |
| F-10 | FAIL-SAFE NITE-BRITES | HCS-70S-MT-QRS-PB-120 CLI-070S-MT-PE-PX-Q | SURFACE MOUNTED HIGH PRESSURE SODIUM FIXTURE WITH CAST ALUMINUM HOUSING, POLYCARBONATE PRISMATIC LENS, DARK BRONZE FINISH, HIGH POWER FACTOR MULTI-TAP BALLAST, 120 VOLT PHOTOCELL, AND QUARTZ RESTRIKE SYSTEM. | 70 W HPS ED-17 70Q-DC |
| F-11 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | CS4-232-EU-CSWG4 T232-UNV-1/2-EB10I-CG-4 SW4S232-UNV-HI/AWG3W-CSP C132-MVDLT-GEB10IS-WG4 S232-SS010-UE/WG240 SS232-UNV-EB81-WG/SS-4FT-U | 4 FT, 2 LAMP SURFACE MOUNTED FLUORESCENT STRIPLIGHT WITH WIRE GUARD AND ONE 2 LAMP, <10% THD ELECTRONIC BALLAST | 2F32T8/ADV835/EW 30 WATT |
| F-12 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | CH4-132-EU N132-UNV-1/1-EB10I SN4S132-UNV-HI C132-MVOLT-GEB10IS S132-SS010-UE SN132-UNV-EB81 | 4 FT, 1 LAMP SURFACE MOUNTED FLUORESCENT STRIPLIGHT WITH ONE 1 LAMP <10% THD ELECTRONIC BALLAST | 1F32T8/ADV835/EW 30 WATT |
| F-13 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | 5PA24-332G-RAA12. 125-S-3ED-120 2DPGS332-RA21-120-1/3-EDB PRS2GRFVI332-120-H3DIM 2SPGB-332RW-A12125-120-GEBDIM GN-A125-332-FD-SSOD-120 2GCB-RA-332-A125-120-DEB81 | 2' x 4', 3 LAMP, LAY-IN FLUDRESCENT FIXTURE WITH REGRESSED FLOATING DOOR, BLACK REVEAL, 0.125" THICK ACRYLIC PRISMATIC LENS, AND ONE 3 LAMP 120 VOLT ELECTRONIC DIMMING BALLAST EQUAL TO ADVANCE MARK 10. | |
| F-14 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | 5PA24-332G-RAA12. 125-S-ED/E-120 2DPGS332-RA21-120-1/21-EDB/EB10I PRS2GRFVI332-120-H2DIM/HI 2SPGB-332RW-A12125-120-GEBDIM GN-A125-332-FD-SSOD/SSU10-120 2GCB-RA-332-A125-120-DEB81/EB81 | SAME AS F-13 EXCEPT WITH DNE 2 LAMP ELECTRONIC DIMMING BALLAST EQUAL TO ADVANCE MARK 10 WIRED TO DUTBOARD LAMPS, AND DNE 1 LAMP <10% THD ELECTRONIC BALLAST WIRED TO INBOARD LAMP FOR CONNECTION TO UNSWITCHED EMERGENCY LIGHTING BRANCH CIRCUIT. | 3F32T8/ADV835/EW 30 WATT |
| F-15 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | RO4-232-EU SJ-232-UNV-1/2-EB10I JS4C232-UNV-HI CB-232-MVOLT-1/2-GEB10IS F12-232-A-SSO10-UE CR-232A-UNV-EB81 | 4 FT, 2 LAMP SURFACE MOUNTED 'CORRIDOR' FLUORESCENT FIXTURE WITH ACRYLIC PRISMATIC LENS AND ONE 2 LAMP <10% THD ELECTRONIC BALLAST. | 2F32T8/ADV835/EW 30 WATT |
| F-16 | COLUMBIA DAY-BRITE LIGHTOLIER LITHONIA LSI METALUX | CSR8-232-4EU TIA232-UNV-1/4-EB10I KW8A232-UNV-H4 TLA232-MVDLT-1/4-GEB10IS F20-232-2-SSD10-U-UE 8TIA-232-UNV-EB81 | 8 FT, 2 LAMP ROW, TANDEM, SURFACE MOUNTED INDUSTRIAL FLUORESCENT STRIPLIGHT WITH OPEN REFLECTOR AND ONE 4 LAMP, <10% THD ELECTRONIC BALLAST | 4F32T8/ADV835/EW 30 WATT |
| F-17 | DAY-BRITE LIGHTOLIER LITHONIA WILLIAMS | WB232-VCP-UNV-1/2-EB10I GSW4232-UNV-HI VW-232-ACR-MVOLT-GEB10IS V5-20-232-DR-EBLH1-UNV | 4 FT, 2 LAMP, FLUORESCENT WALL BRACKET WITH CLEAR PRISMATIC HIGH IMPACT ACRYLIC LENS AND ONE 2 LAMP <10% THD ELECTRONIC BALLAST | |
| F-18 | ECLIPSE WILLIAMS | 85-S-TTT32-EBU-93 PHSQ12-232-EB-UNV | RECESSED COMPACT FLUORESCENT FIXTURE WITH NOMINAL 12" SQUARE HOUSING, TEMPERED GLASS LENS, WHITE TRIM, AND <10% THD ELECTRONIC BALLAST | 2CFM32W/35K |

^{1.} PROVIDE EXTRA MATERIAL STOCK OF LAMPS AND BALLASTS, SEE SPECIFICATION SECTION 16500.
2. BURN IN ALL FLUORESCENT AND HID LAMP FOR 100 CONTINUOUS HOURS PRIOR TO SUBSTANTIAL COMPLETION.
LAMP BURN IN IS CRITICAL FOR DIMMER CONTROLLED LAMPS TO OBTAIN FULL DIMMING RANGE AND
FOR OCCUPANCY SENSOR CONTROLLED LAMPS TO OBTAIN FULL LAMP LIFE.

KEYED NOTES:

- (I) REPLACE ALL EXISTING FIXTURES IN ROOM WITH NEW FIXTURES INDICATED AND CONNECT TO EXISTING CIRCUIT AND SWITCHES UNLESS NOTED OTHERWISE. EXISTING CIRCUIT IS SHOWN FOR REFERENCE.
- EXISTING CIRCUIT IS SHOWN FOR REFERENCE.

 (2) EXISTING FIXTURE CONNECTED TO NORMAL POWER BRANCH CIRCUIT. PROVIDE NEW CONNECTION TO EMERGENCY BRANCH CIRCUIT AS SHOWN. CONNECT
- 3 PROVIDE NEW EXIT LIGHT IN EXISTING CEILING AND CONNECT TO EXISTING EMERGENCY BRANCH CIRCUIT AS SHOWN.

EMERGENCY CIRCUIT TO ONE INBOARD LAMP FOR 3 LAMP FIXTURES.

- (4) REPLACE EXISTING BATTERY BACK-UP EXIT/EMERGENCY LIGHT WITH NEW EXIT LIGHT AND CONNECT TO EMERGENCY BRANCH CIRCUIT AS SHOWN.
- (5) EXISTING FIXTURE WITH COMPACT FLUORESCENT LAMP TO REMAIN.

ROOF STAIR

OFFICE O F-6

1 O F-6

0 F-6 0 F-6

209A 2A-2

GENERAL NOTES:

LABORATORY (1)2A-4,6

O F-6

O F-6

O F-6

O F-6

O F-6

O F-6

F-6

O F-6

0

MUSEUM (1) 2A-11

O F-6

O F-6

F-6

CHEMISTRY LAB (1) 2A-1,9

CHEMISTRY PREP/WORK ROOM (1) 2A-1

O F-6

0 (2) F-6 EM EMA-1

> O F-6

O F-6

O F-6

(2) F-6 EM


EMA-3

0 2 F-6 EM

EMA-3

O F-6

- COORDINATE FIXTURE LOCATIONS WITH ARCHITECT'S REFLECTED CEILING PLAN, CEILING CONTRACTOR, BUILDING STRUCTURE, MECHANICAL EQUIPMENT & DUCTWORK LOCATIONS, ETC.
- WHERE BRANCH CIRCUIT HOMERUNS INDICATE WIRE SIZES, USE THAT SIZE WIRE THROUGHOUT THE BRANCH CIRCUIT, INCLUDING SWITCH LEGS, ETC.
- 3. TAKE ALL PRECAUTIONS NECESSARY TO AVOID DAMAGE TO THE EXISTING BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE GENERAL CONTRACTOR.



HFSArchitects

ARCHITECTURE
INTERIORS
PLANNING

1484 South State
Salt Lake City, Utah 84115

801-596-0691/F: 596-0693

www.hfsa.com

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

| В | MARK | DATE | DESCRIPTION |
|---|--|--------------------------------|---|
| | | PROJECT NO: | 30 JANUARY 20 070436 |
| | CAD DWG DRAWN B CHECKED DESIGNED DWG TYP | Y: D BY: E: CTURAL PHAS CONSTR | 0730 0730 E-101.c W.E R.G W.E ELECTRIC E: UCTION DOCUMEN |
| Α | | 2ND | FLOOR ING PLAN |

2ND FLOOR LIGHTING PLAN

SCALE: 1/8" = 1'-0" 5





| | FO | | 4= | NIT | | | | \ | | | | | |
|---------|---------------------------|-------------------|-------|-------|---------------|---------|---------|-------------------|------------------|---------------|------------------------------|--|--|
| | EQUIPMENT SCHEDULE | | | | | | | | | | | | |
| EQUIP. | DESCRIPTION | CIRCUIT NUMBER | VOLTS | PHASE | WATTS H.P. | BREAKER | FURNISH | TARTER INSTALL | S SIZE | AUX. CONT. | LOCATION | | |
| EF 1 | EXHAUST FAN, ROOF MOUNTED | IC-42 | 12Ø | 1 | 1/2 HP | IP-2ØA | E | E | \$TH | - | ON ROOF CADAYER LAB 118 | | |
| MA 1 | MAKE-UP AIR UNIT | G-38 | 208 | 3 | 72.4 AMPS | 3P-100A | М | M | М | - | ON ROOF (CADAVER LAB 118) | | |
| FPB 1 | FAN POWERED VAV BOX | D2-4Ø | 120 | 1 | 1/2 HP | IP-20A | E | E | \$ _{TH} | - | BIOLOGY LAB 127 | | |
| FPB 2 | FAN POWERED VAV BOX | D2-41 | 120 | 1 | 1/2 HP | IP-20A | E | E | \$ _{TH} | - | MICRO BIOLOGY LAB 129 | | |
| FPB 3 | FAN POWERED VAV BOX | D-32 | 120 | 1 | 1/2 HP | IP-20A | E | E | \$ _{TH} | - | BIOTECH LAB 136 | | |
| FPB | FAN POWERED VAY BOX | IC-4Ø | 120 | 1 | 1/2 HP | IP-20A | E | E | \$ _{TH} | - | PHYSIOLOGY 117 | | |

E - ELECTRICAL CONTRACTOR M - MECHANICAL CONTRACTOR

ADDITIVE ALTERNATE NO. 1 - DATA CABLES:

1. PROVIDE NEW PLENUM RATED CATEGORY 5E DATA CABLES FROM EACH NEW DATA OUTLET TO EXISTING TELEPHONE/DATA TERMINALS UNDER ADDITIVE ALTERNATE NO. 1.

A3 1ST FLOOR POWER PLAN

SCALE: 1/8" = 1'-0" 3 0 4' 8' 16'

2. LEAVE MINIMUM 12" SLACK CABLE AT DATA OUTLETS FOR CABLE TERMINATIONS BY OWNER.

KEYED NOTES:

- PROVIDE NEW DUPLEX RECEPTACLE ABOVE NEW CEILING FOR CEILING MOUNTED PROJECTOR TO BE FURNISHED AND INSTALLED BY OWNER.
- $\langle 2
 angle$ provide 2" conduit under floor and surface raceway to ceiling for OWNER FURNISHED PROJECTOR CABLES. SAWCUT, REMOVE, AND REPAIR EXISTING CONCRETE FLOOR TO INSTALL NEW CONDUIT. SEE DETAIL INDICATED.
- (3) REPLACE EXISTING RECEPTACLE IN FACE OF CABINET WITH NEW GFCI RECEPTACLE AND RECONNECT EXISTING BRANCH CIRCUIT.
- 4 PROVIDE RECEPTACLES AND DATA OUTLETS IN NEW CASEWORK, SEE ARCHITECT'S DETAILS. CONNECT RECEPTACLES WITHIN CASEWORK USING 1/2" LIQUID-TIGHT FLEXIBLE STEEL CONDUIT.
- (5) EXISTING DUAL CHANNEL, POWER AND DATA, SURFACE MULTI-OUTLET ASSEMBLY TO REMAIN. SHOWN FOR REFERENCE ONLY.
- (6) EXISTING RECEPTACLE BRANCH CIRCUIT INTERRUPTED BY DEMOLITION. CONNECT TO NEW BRANCH CIRCUIT AS SHOWN.
- 1) PROVIDE NEW COMBINATION POWER/DATA FLUSH FLOOR BOXES. FIELD COORDINATE EXACT LOCATION WITH NEW COMPUTER LAB TABLES.
- (8) PROVIDE NEW I" DATA CONDUIT FROM NEW FLOOR BOXES TO NEW CABLE TRAY N TUNNEL BELOW, SIMILAR TO DETAIL B5/E-601.
- 9 PROVIDE NEW DUAL CHANNEL, POWER AND DATA, SURFACE MULTI-OUTLET ASSEMBLY ABOVE NEW BASE CABINETS.
- (10) CONNECT TO NEW SURFACE MULTI-OUTLET ASSEMBLY FROM FLUSH MOUNTED OUTLET BOXES IN NEW WALL. INSTALL CONDUIT FROM OUTLET BOXES DOWN TO TUNNEL BELOW EXCEPT POWER CONDUITS MAY INSTALLED IN CEILING SPACE. COORDINATE INSTALLATION WITH NEW MECHANICAL DUCTWORK.
- (II) EXTEND DUAL CHANNEL SURFACE RACEWAY TO CEILING AND MAKE CEILING CONNECTION SIMILAR TO DETAIL A5/E-601.

KEYED NOTES:

SPACE.

WITH OWNER.

- $\langle 12 \rangle$ FLUSH MOUNTED DATA OUTLET WITH 3/4" CONDUIT TO CABLE TRAY IN TUNNEL
- 13) REPLACE ALL EXISTING RECEPTACLES IN ROOMS INDICATED WITH NEW RECEPTACLES AND COVERPLATES TO MATCH COLOR AND STYLE OF OTHER NEW WIRING DEVICES.

CEILING SPACE TO CABLE TRAY IN TUNNEL BELOW FOR DATA CABLES FROM

LOCATION WITH EXISTING CONDITIONS. DATA CABLE WILL BE INSTALLED IN NEW

RACEWAY SYSTEM PROVIDED FOR CEILING PROJECTOR CABLES TO CEILING

POLE WITH 2" GROMMETTED OPENING AT BOTTOM FOR DATA CABLES AND

(18) TERMINATE NEW VERTICAL SURFACE RACEWAY BASE APPROXIMATELY 4" ABOVE

(19) PROVIDE NEW RECEPTACLE IN EXISTING SURFACE RACEWAY FOR FREEZER TO

BE RELOCATED FROM NORTH COUNTER AND CONNECT TO EXISTING CIRCUIT

AND BELOW EXISTING HORIZONTAL SURFACE RACEWAY. EXTEND COVER OVER EXISTING HORIZONTAL SURFACE RACEWAY. FIELD COORDINATE REQUIREMENTS

CEILING MOUNTED DATA OUTLETS, COMMUNICATION POLES, ETC..

PROJECTOR TO BE FURNISHED AND INSTALLED BY OWNER.

OWNER FURNISHED PROJECTOR CABLES.

SERVING THE FREEZER AT THE EXISTING LOCATION.

(15) PROVIDE NEW DATA OUTLET ABOVE NEW CEILING FOR CEILING MOUNTED

(16) PROVIDE NEW DATA OUTLET IN EXISTING CABINET. FIELD COORDINATE

- (14) PROVIDE 2" CONDUIT CONCEALED IN NEW WALL SPACE FROM ACCESSIBLE
 - 3. WHERE BRANCH CIRCUIT HOMERUNS INDICATE WIRE SIZES, THE BRANCH CIRCUIT SHALL BE THAT SIZE WIRE THROUGHOUT, INCLUDING SWITCH LEGS, ETC.

MILLWORK AND FURNITURE LOCATIONS PRIOR TO ROUGHING IN.

GENERAL NOTES:

MECHANICAL CONTRACTOR.

WHETHER SPECIFICALLY NOTED OR NOT.


- 4. ALL EXISTING RECEPTACLES, OUTLETS, ETC., SHOWN ON THIS SHEET ARE TO REMAIN
- UNLESS SPECIFICALLY NOTED OTHERWISE.

1. COORDINATE MECHANICAL EQUIPMENT LOCATIONS WITH MECHANICAL PLANS AND

2. FIELD COORDINATE LOCATION OF ALL NEW RECEPTACLES AND OUTLETS WITH

- 5. PROVIDE A SEPARATE NEUTRAL FOR EACH NEW RECEPTACLE BRANCH CIRCUIT. 6. PROVIDE AN INSULATED GREEN EQUIPMENT GROUND WIRE IN ALL NEW RACEWAYS
- 7. TAKE ALL PRECAUTIONS NECESSARY TO AVOID DAMAGE TO THE EXISTING BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW (17) PROVIDE NEW WIREMOLD 25DTC-V, OR EQUAL, COMMUNICATION VERTICAL DROP CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS

WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE GENERAL CONTRACTOR.



HFSArchitects **A**RCHITECTURE

PLANNING 1484 South State Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

NTERIORS

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

DESCRIPTION

30 JANUARY 2008

0730 E-101 dwg

ELECTRICAL

07043640

0730.01

W.B.G.

MARK DATE

DATE:

AGENCY PROJECT NO:

ARCHITECTURAL PHASE:

HFSA PROJECT NO:

CAD DWG FILE NO:

CHECKED BY:

DESIGNED BY:

DWG TYPE:

SHEET TITLE


| \ | | | | |
|---|----------|-------------|--|--|
| | | | | |
| L | |] | | |
| | = | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | H | = | | |
| | | | | |
| | | - - - | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | \vdash | = | | |
| | | | | |
| | | = | | |
| | | = | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| Г | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| / | | | | |
| | | | | |
| | | | | |
| \ | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

1ST FLOOR POWER PLAN

CONSTRUCTION DOCUMENTS

EP101

6 OF 9 (ELECT.)



N

ADDITIVE ALTERNATE NO. 1 - DATA CABLES:

- 1. PROVIDE NEW PLENUM RATED CATEGORY 5E DATA CABLES FROM EACH NEW DATA OUTLET TO EXISTING TELEPHONE/DATA TERMINALS UNDER ADDITIVE ALTERNATE NO. 1.
- 2. LEAVE MINIMUM 12" SLACK CABLE AT DATA OUTLETS FOR CABLE TERMINATIONS BY OWNER.
- 3. LEAVE MINIMUM 3 FT SLACK CABLE AT TELEPHONE DATA TERMINALS FOR CABLE TERMINATIONS BY OWNER.
- 4. INSTALL CABLES IN CONDUIT AND/OR CABLE TRAY UNLESS NOTED OTHERWISE.
 CABLES INSTALLED ABOVE NEW ACCESSIBLE CEILINGS WILL NOT REQUIRE
 RACEWAY BUT SHALL BE SUPPORTED FROM STRUCTURE WITH TIE-WRAPS OR
 OTHER MEANS ACCEPTABLE TO THE ARCHITECT AND ENGINEER.

KEYED NOTES:

- PEMOVE EXISTING RECEPTACLES FROM EXISTING TABLES TO BE REMOVED.
 RETAIN EXISTING BRANCH CIRCUIT AS REQUIRED FOR CONNECTION TO NEW RECEPTACLES. REMOVE ALL ABANDONED WIRING, CONDUIT, BOXES, ETC...
- 2 PROVIDE NEW RECEPTACLES AND DATA OUTLETS IN NEW TABLES, SEE ARCHITECT'S DETAILS. CONNECT RECEPTACLES UNDER TABLES USING 1/2" LIQUID-TIGHT FLEXIBLE STEEL CONDUIT ARRANGED TO MINIMIZE AMOUNT OF EXPOSED CONDUIT.
- EXPOSED CONDUIT.

 3 CONNECT NEW RECEPTACLES TO EXISTING BRANCH CIRCUIT ABANDONED BY DEMOLITION. PROVIDE CONDUIT STUB-UP SIMILAR TO DETAIL C5/E-6ØI EXCEPT INSTALL NEW CONDUIT IN 1ST FLOOR CEILING SPACE.
- 4 PROVIDE NEW BRANCH CIRCUIT COMPLETE TO EXISTING PANEL FOR NEW RECEPTACLES. PROVIDE CONDUIT STUB-UP SIMILAR TO DETAIL C5/E-6ØI EXCEPT INSTALL NEW CONDUIT IN 1ST FLOOR CEILING SPACE.
- (5) PROVIDE I" CONDUIT FROM NEW TABLES TO EXISTING TELEPHONE/DATA TERMINAL BOARD IN ROOM 114 ON 1ST FLOOR. TERMINATE NEW CONDUIT AT TABLE SIMILAR TO DETAIL B5/E-6ØI EXCEPT INSTALL CONDUIT IN 1ST FLOOR CEILING SPACE.
- PROVIDE TWO NEW SQUARE D TYPE 'QOB-VH' IP-20A CIRCUIT BREAKERS IN EXISTING PANEL '2B' TO SERVE NEW CIRCUITS *5 AND *38. CONNECT ADDITIONAL NEW CIRCUITS TO SPARE IP-20A BREAKERS.

EXIST. PANEL '209A'


120/208 V, 1¢ —

GENERAL NOTES:

- 1. FIELD COORDINATE LOCATION OF ALL NEW RECEPTACLES AND OUTLETS WITH MILLWORK AND FURNITURE LOCATIONS PRIOR TO ROUGHING IN.
- 2. WHERE BRANCH CIRCUIT HOMERUNS INDICATE WIRE SIZES, THE BRANCH CIRCUIT SHALL BE THAT SIZE WIRE THROUGHOUT, INCLUDING SWITCH LEGS, ETC.
- 3. ALL EXISTING RECEPTACLES, OUTLETS, ETC., SHOWN ON THIS SHEET ARE TO REMAIN UNLESS SPECIFICALLY NOTED OTHERWISE.
- 4. PROVIDE A SEPARATE NEUTRAL FOR EACH NEW RECEPTACLE BRANCH CIRCUIT.
- 5. PROVIDE AN INSULATED GREEN EQUIPMENT GROUND WIRE IN ALL NEW RACEWAYS WHETHER SPECIFICALLY NOTED OR NOT.

L — — — —

6. TAKE ALL PRECAUTIONS NECESSARY TO AVOID DAMAGE TO THE EXISTING BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE GENERAL CONTRACTOR.



HFSArchitects ARCHITECTURE

PLANNING

1484 South State
Salt Lake City, Utah 84115
801-596-0691/F: 596-0693
www.hfsa.com

NTERIORS

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

| 2 2 2 2 2 3 2 3 3 7 3 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 | 2B-36 P 4 P 2 P 2 P 1 P 1 P 1 P 1 P 1 P 1 P 1 P 1 |
|--|--|
| CORRIDOR (201) EXIST. PANEL 24 1207208 V, 39 | |
| ELECT 120/208 V, 34 EXIST. PANEL '2D' 120/208 V, 34 OFFICE 2003 CORRIDOR 2004 CHEMISTRY PREPAUORK RO | |
| CHEMISTRY LAB 201 | STORAGE 202A |

2ND FLOOR POWER PLAN SCALE: 1/8" = 1'-0" 5




MARK DATE DESCRIPTION DATE 30 JANUARY 2008 AGENCY PROJECT NO: 07043640 0730.01 HFSA PROJECT NO: CAD DWG FILE NO: 0730 E-101.dwg W.B.G. CHECKED BY: R.G.K. DESIGNED BY: W.B.G. DWG TYPE: ELECTRICAL

ARCHITECTURAL PHASE:
CONSTRUCTION DOCUMENTS

2ND FLOOR POWER PLANS

EP102

7 OF 9 (ELECT.)



EXIST. PANEL '209A'

. _ _ _ _ _ _ _

12Ø/2Ø8 V, 1¢ —

LABORATORY

| EXISTING PANEL '1C' | | | | MAIN | IN PANEL ' | MDP' | | | | 10,000 A. I. C. FULL | _Y F | RATED | |
|--------------------------------|-------|------------------|-----------|---------------------------|------------|---------|-----------------|-----|------|-------------------------------|------|-------|-----|
| SQUARE D TYPE 'NQOD' | | | | EAST WING ELECTRICAL ROOM | | | | | | 120/208 VOLT, 3 PHASE, 4 WIRE | | | |
| 3 POLE 225 AMP MAIN LUGS | | | | | | | SURFACE MOUNTED | | | | | | |
| CIR BRKR PECCELETIEN | N□. | ND. | CIRCUIT | PHA | ASE LOAD - | VA | CIRCUIT | ND. | ND. | DECODIDATION | В | RKR | CIR |
| NO. P AMPS DESCRIPTION | LTS | REC | LOAD | PHASE A | PHASE B | PHASE C | LOAD | REC | LTS | DESCRIPTION | Р | AMPS | N□. |
| 1 1 20 LTS, ROOM 117 | 16 | | 1,380 | 2, 380 | | | 1,000 | | | COMPUTERS 118 (1,2,3,4)* | 1 | 20 | 2 |
| 3 LTS, ROOM 118 | 16 | | 1,380 | | 2, 380 | | 1,000 | | | COMPUTERS 118 (5,6,7,8)* | | | 4 |
| 5 REC, RM 118 FRONT DESK | | 2 | 360 | | | 1, 360 | 1,000 | | | COMP. 118 (9,10,11,12)* | | | 6 |
| 7 REC, PROJ & DESK 116 * | | | 1,000 | 2,000 | | | 1,000 | | | C□MP. 118 (13,14,15,16)* | | | 8 |
| 9 REC, PROJECTOR RM 118 | | 1 | 180 | | 1, 180 | | 1,000 | | | C□MP. 118 (17,18,19,20)* | | | 10 |
| 11 REC, RM 118, EAST WALL | | 3 | 540 | | | 1,540 | 1,000 | | | COMP. 118 (21,22,23,24)* | | | 12 |
| 13 FLOOR OUTLET - WEST * | | | 1,000 | 2,000 | | | 1,000 | | | OUTSIDE OUTLET* | | | 14 |
| 15 FLOOR OUTLET - CENTER * | | | 1,000 | | 1,000 | | | | | SPARE | | | 16 |
| 17 | | | 1,000 | | | 1, 360 | 360 | 2 | | REC, RM 117, DESK & CNTR | | | 18 |
| 19 S. E. DUTLETS * | | | 1,000 | 1, 180 | | | 180 | 1 | | REC ON ROOF | | | 20 |
| 21 N. OUTLETS * | | | 1,000 | | 1, 360 | | 360 | 2 | | REC, RM 118, SE COUNTER | | | 22 |
| 23 MIDDLE * | | | 1,000 | | | 1, 360 | 360 | 2 | | REC, RM 118, NE COUNTER | | | 24 |
| 25 FLOOR REC, ROOM 117 | | 4 | 720 | 900 | | | 180 | 1 | | REC, PROJECTOR RM 117 | | | 26 |
| 27 FLOOR REC, ROOM 117 | | 4 | 720 | | 1, 260 | | 540 | 3 | | REC, RM 117, SD. COUNTER | | | 28 |
| 29 FLOOR REC, ROOM 117 | | 4 | 720 | | | 1, 260 | 540 | 3 | | REC, RM 117, SD. COUNTER | | | 30 |
| 31 FLOOR REC, ROOM 117 | | 4 | 720 | 1,080 | | | 360 | 2 | | REC, RM 117 EAST WALL | | | 32 |
| 33 FLOOR REC, ROOM 117 | | 4 | 720 | | 1,080 | | 360 | 2 | | REC, RM 117 EAST WALL | | | 34 |
| 35 FLOOR REC, ROOM 117 | | 4 | 720 | | | 1, 260 | 540 | 3 | | REC, RM 117, NO. COUNTER | | | 36 |
| 37 SPARE | | | | 540 | | | 540 | 3 | | REC, RM 117, ND. COUNTER | | | 38 |
| 39 REC, RM 117, WEST WALL | | 2 | 360 | | 1, 535 | | 1, 175 | | | FAN PWRD VAV BOX RM 117 | | | 40 |
| 41 1 20 SPARE | | | | | | 1, 175 | 1, 175 | | | RM 118 EXHAUST FAN | 1 | 20 | 42 |
| | | | | 10, 080 | 9, 795 | 9, 315 | | | | | | | |
| TOTAL | _ CON | NEC ⁻ | TED LOAD: | 29, 190 | VA | 81 AMPS | | FEE | DER: | EXISTING 4 #2/0, 2" C | | | |
| CALCULATED FEEDER | | | | 22, 840 | | 63 AMPS | | | | | | | |

^{*} EXISTING CIRCUIT TO REMAIN - FIELD VERIFY AND INCLUDE ON NEW TYPEWRITTEN CIRCUIT INDEX. LOAD IS ESTIMATED.

| | | | G PANEL 'G' | | | | | | | | | | 10,000 A. I. C. FUL | | | |
|------------|---|-------------|--------------------------|------|------------|-----------|---------|-----------------------|----------|-----------------|------------|------|--------------------------|----|--------------|----------|
| | | | HAMMER TYPE 'PB' | | | | | | | | | | 120/208 VOLT, 3 PHASE | | | |
| | | | 300 AMP MAIN BREAKER | T | T | | 511 | 105 L 54D | 1/4 | | T | T | SURFACE | _ | | T |
| CIR ND. | | RKR AMPS | DESCRIPTION | | ND. REC | | PHASE A | ASE LOAD - PHASE B | PHASE C | CIRCUIT LOAD | ND. REC | | DESCRIPTION | _ | BRKR AMPS | CI ND |
| 1 | 1 | 20 | LTS, ROOM 116 | 16 | | 1,380 | 1,380 | | | | | | SPARE | 1 | 20 | 2 |
| 3 | | | LTS, OFFICES 115A & 115B | 4 | | 330 | | 330 | | | | | SPARE | Ī | | 4 |
| 5 | | | LTS, ROOM 115 | 16 | | 1,380 | | | 1, 380 | | | | SPARE | | | 6 |
| 7 | | | SPARE | | | | 1,000 | | | 1,000 | | | REC, ROOM 117 * | | | 8 |
| 9 | | | SPARE | | | | | 1,000 | | 1,000 | | | REC, ROOM 117 * | | | 10 |
| 11 | | | REC, PROJECTOR RM 116 | | 2 | 360 | | | 1, 360 | 1,000 | | | REC, ROOM 117 * | | | 12 |
| 13 | | | REC, TABLES, RM 116 | | 4 | 720 | 1,550 | | | 830 | | | RM 17 EX. FAN * | | | 14 |
| 15 | | | REC, TABLES, RM 116 | | 4 | 720 | | 1, 720 | | 1,000 | | | REC, N. W. DUTSIDE * | | | 16 |
| 17 | | | REC, TABLES, RM 116 | | 4 | 720 | | | 1, 720 | 1,000 | | | ROOM 116 DESK * | | | 18 |
| 19 | | | REC, TABLES, RM 116 | | 4 | 720 | 720 | | | | | | SPARE | | | 20 |
| 21 | | | REC, TABLES, RM 116 | | 4 | 720 | | 720 | | | | | SPARE | | | 22 |
| 23 | | | REC, TABLES, RM 116 | | 4 | 720 | | | 720 | | | | SPARE | | | 24 |
| 25 | | | REC, ROOM 115 * | | | 1,000 | 1,000 | | | | | | SPARE | | | 26 |
| 27 | | | REC, ROOM 115 * | | | 1,000 | | 1,000 | | | | | SPARE | | | 28 |
| 29 | | | FLOOR REC, ROOM 116 * | | | 1,000 | | | 1,000 | | | | SPARE | | | 30 |
| 31 | | | SPARE | | | | 0 | | | | | | SPARE | | | 32 |
| 33 | | | SPARE | | | | | 0 | | | | | SPARE | | | 34 |
| 35 | | | SPARE | | | | | | 0 | | | | SPARE | 1 | 20 | 36 |
| 37 | 1 | 20 | SPARE | | | | 8, 685 | | | 8, 685 | | | RM 118 MAKE-UP AIR UNIT | 3 | 100+ | 38 |
| 39 | 2 | 50 | SPARE | | | | | 8, 685 | | 8, 685 | | | - | - | - | 40 |
| 41 | - | - | _ | | | | | | 8, 685 | 8, 685 | | | _ | - | _ | 42 |
| | | | | | | | 14, 335 | 13, 455 | 14, 865 | | | | | | | |
| | | | TOTA | L CO | NNEC | TED LOAD: | 42, 655 | VA | 118 AMPS | I | FEE | DER: | EXISTING 4 #350 MCM RHW, | 3- | -1/2" | С |
| | | | CALCULATED FEEDER | DEM | AND, | NEC 220: | 48, 601 | VA | 135 AMPS | | | | | | | |

* EXISTING CIRCUIT TO REMAIN - FIELD VERIFY AND INCLUDE ON NEW TYPEWRITTEN CIRCUIT INDEX. LOAD IS ESTIMATED. + PROVIDE NEW CUTLER HAMMER TYPE 'CHB' BRANCH CIRCUIT BREAKER, RATING AS INDICATED, TO REPLACE EXISTING SPARE CIRCUIT BREAKERS.


| | | | IG PANEL 'D' SHOUSE TYPE 'NQC' | | | | | | | | | | 10,000 A. I. C. FULL 120/208 VOLT, 3 PHASE, | | | |
|-----|---|------|-----------------------------------|------|-------|-----------|---------|------------|----------|---------|-----|------|--|---|------|----|
| | | | 225 AMP MAIN LUGS | | | | | | | | | | SURFACE | | | |
| CIR | | RKR | DESCRIPTION | N□. | N□. | CIRCUIT | PHA | ASE LOAD - | VA | CIRCUIT | ND. | N□. | DESCRIPTION | E | BRKR | CI |
| ND. | Ρ | AMPS | DESCRIFTION | LTS | REC | LOAD | PHASE A | PHASE B | PHASE C | LOAD | REC | LTS | DESCRIPTION | Р | AMPS | N |
| 1 | 1 | 20 | LTS, RM 135 | 4 | | 420 | 1, 320 | | | 900 | 5 | | REC, RM 136 WALL & DESK | 1 | 20 | í |
| 3 | | | LTS, ROOM 136 | 16 | | 1,380 | | 1,560 | | 180 | 1 | | REC, RM 135 SO. WALL | | | 4 |
| 5 | | | LTS, ROOM 137 | 16 | | 1, 380 | | | 1, 920 | 540 | 3 | | REC, RM 136 SD. COUNTER | | | (|
| 7 | | | SPARE | | | | 540 | | | 540 | 3 | | REC, RM 136 SD. COUNTER | | | 8 |
| 9 | | | REC, RM 135 EAST COUNTER | | 2 | 360 | | 720 | | 360 | 2 | | REC, RM 136 EAST WALL | | | 10 |
| 11 | | | REC, RM 135 EAST COUNTER | | 2 | 360 | | | 720 | 360 | 2 | | REC, RM 136 EAST WALL | | | 18 |
| 13 | | | REC, RM 135 EAST COUNTER | | 1 | 180 | 900 | | | 720 | 4 | | REC, RM 136 TABLES | | | 14 |
| 15 | | | REC, RM 135 WEST COUNTER | | 2 | 360 | | 1,080 | | 720 | 4 | | REC, RM 136 TABLES | | | 10 |
| 17 | | | REC, RM 135 WEST COUNTER | | 2 | 360 | | | 1,080 | 720 | 4 | | REC, RM 136 TABLES | | | 18 |
| 19 | | | REC, RM 135 WEST COUNTER | | 1 | 180 | 900 | | | 720 | 4 | | REC, RM 136 TABLES | | | 20 |
| 21 | | | RM 137 PLUGS * | | | 1,000 | | 1, 720 | | 720 | 4 | | REC, RM 136 TABLES | | | 22 |
| 23 | | | RM 137 PLUGS * | | | 1,000 | | | 1, 720 | 720 | 4 | | REC, RM 136 TABLES | | | 24 |
| 25 | | | RM 137 PLUGS * | | | 1,000 | 1,540 | | | 540 | 3 | | REC, RM 136 NO. COUNTER | | | 26 |
| 27 | | | RM 137 PLUGS * | | | 1,000 | | 1,540 | | 540 | 3 | | REC, RM 136 NO. COUNTER | | | 28 |
| 29 | 1 | 20 | RM 137 PLUGS * | | | 1,000 | | | 1, 180 | 180 | 1 | | REC, RM 136 CLG PROJECTOR | | | 30 |
| 31 | 3 | 100+ | NEW PANEL 'D2' | | | 7,140 | 8, 315 | | | 1, 175 | | | FAN PWRD VAV BOX RM 136 | | | 32 |
| 33 | - | = | - | | | 7, 415 | | 7, 615 | | 200 | | | SPRINKLER CLOCK * | | | 34 |
| 35 | - | - | - | | | 6, 215 | | | 6, 215 | | | | SPARE | 1 | 20 | 36 |
| 37 | 2 | 70 | SPARE | | | | 0 | | | | | | | | | |
| | - | - | (SUBFEED BREAKER) | | | | | 0 | | | | | | | | |
| | | | | | | | | | 0 | | | | | | | |
| | • | | | | | | 13, 515 | 14, 235 | 12, 835 | | | | | | | |
| | | | ТПТАІ | _ СП | NNEC. | TED LOAD: | 40, 585 | VA | 113 AMPS | | FEE | DER: | 4 #1/0 RHW, 2" C | | | |
| | | | CALCULATED FEEDER | | | | 31,610 | | 88 AMPS | | | | | | | |

* EXISTING CIRCUIT TO REMAIN - FIELD VERIFY AND INCLUDE ON NEW TYPEWRITTEN CIRCUIT INDEX. LOAD IS ESTIMATED. + PROVIDE NEW CUTLER HAMMER TYPE 'QC' BRANCH CIRCUIT BREAKER, RATING AS INDICATED, TO REPLACE EXISTING SPARE CIRCUIT BREAKERS.

| NEW PANEL ' D2' * 10,000 A. I. C. FUL | | | | | | | | | | _Y F | RATEJ | Ĵ | | | | |
|---|---------------------|-----|---------------------------|----|---------|--------------|---------|-------------------|---------|--------|-------|-------------|---------------------------|---|------|-------|
| TYPE 'PRL1α' 120/208 VOLT, 3 PHASE, 4 | | | | | | | | | | | 4 | WIRE | Ξ | | | |
| 3 POLE 100 AMP MAIN LUGS SURFACE MOUNTE | | | | | | | | | | | JNTE] | J | | | | |
| | IR BRKR DESCRIPTION | | | | CIRCUIT | PHASE LOAD - | | VA | | N□. | | DESCRIPTION | BRKR | | CIR | |
| ND. F | P A | MPS | | | REC | LOAD | PHASE A | PHASE B | PHASE C | LOAD | REC | LTS | DESCRIPTION | Р | AMPS | S NO. |
| 1 | 1 | 20 | LTS, ROOM 129 | 16 | | 1,380 | 1,380 | | | | | | SPARE | 1 | 20 | 2 |
| 3 | | | LTS, ROOM 127 | 16 | | 1,380 | | 1, 380 | | | | | SPARE | | | 4 |
| 5 | | | SPARE | | | | | | 540 | 540 | 3 | | REC, RM 127 EAST COUNTER | | | 6 |
| 7 | | | REC, 129 WALL & DESK | | 5 | 900 | 1,440 | | | 540 | 3 | | REC, RM 127 WALL & DESK | | | 8 |
| 9 | | | SPARE | | | | | 360 | | 360 | 2 | | REC, RM 127 SO. COUNTER | | | 10 |
| 11 | | | SPARE | | | | | | 540 | 540 | 3 | | REC, RM 127 SD. COUNTER | | | 12 |
| 13 | | | REC, RM 129 TABLES | | 4 | 720 | 1,440 | | | 720 | 4 | | REC, RM 127 TABLES | | | 14 |
| 15 | | | REC, RM 129 TABLES | | 4 | 720 | | 1, 440 | | 720 | 4 | | REC, RM 127 TABLES | | | 16 |
| 17 | | | REC, RM 129 TABLES | | 4 | 720 | | | 1, 440 | 720 | 4 | | REC, RM 127 TABLES | | | 18 |
| 19 | | | REC, RM 129 TABLES | | 4 | 720 | 1,440 | | | 720 | 4 | | REC, RM 127 TABLES | | | 20 |
| 21 | | | REC, RM 129 TABLES | | 4 | 720 | | 1, 440 | | 720 | 4 | | REC, RM 127 TABLES | | | 22 |
| 23 | | | REC, RM 129 TABLES | | 4 | 720 | | | 1, 440 | 720 | 4 | | REC, RM 127 TABLES | | | 24 |
| 25 | | | REC, RM 129 SD. COUNTER | | 3 | 540 | 900 | | | 360 | 2 | | REC, RM 127 NO. COUNTER | Ш | | 26 |
| 27 | | | REC, RM 129 SD. COUNTER | | 3 | 540 | | 1,080 | | 540 | 3 | | REC, RM 127 NO. COUNTER | Ш | | 28 |
| 29 | | | REC, RM 129 WEST WALL | | 2 | 360 | | | 540 | 180 | 1 | | REC, RM 127 CLG PROJECTOR | Ш | | 30 |
| 31 | | | REC, RM 129 WEST WALL | | 2 | 360 | 360 | | | | | | SPARE | Ш | | 32 |
| 33 | | | REC, RM 129 NO. COUNTER | | 3 | 540 | | 540 | | | | | SPARE | Ш | | 34 |
| 35 | | | REC, RM 129 NO. COUNTER | | 3 | 540 | | | 540 | | | | SPARE | Ш | | 36 |
| 37 | | | REC, RM 129 CLG PROJECTOR | | 1 | 180 | 180 | | | | | | SPARE | Ш | | 38 |
| 39 | | | SPARE | | | | | 1, 175 | | 1, 175 | | | FAN PWRD VAV BOX RM 127 | Ш | | 40 |
| 41 | 1 | 20 | FAN PWRD VAV BOX RM 129 | | | 1, 175 | | | 1, 175 | | | | SPARE | 1 | 20 | 42 |
| | | | | | | | | 7, 415 | 6, 215 | | | | | | | |
| TOTAL CONNECTED LOAD: | | | | | | | | 20,770 VA 58 AMPS | | | FEE | DER: | 4 #2, 1 #8 GND, 1-1/4" C | | | |
| CALCULATED FEEDER DEMAND, NEC 220: | | | | | | | 18, 630 | VΔ | 52 AMPS | | | | | | | |

^{*} CONNECT NEW PANEL 'D2' TO NEW 3P-100A BREAKER IN EXISTING PANEL 'D' WITH 4 #2, 1 #8 GND, 1-1/4" CONDUIT. SEE PANEL 'D' SCHEDULE ABOVE





FIXTURE SUPPORT NOTES: 1. ALL LIGHTING FIXTURES SHALL BE POSITIVELY ATTACHED TO THE SUSPENDED CEILING SYSTEM. THE ATTACHMENT DEVICE SHALL HAVE A CAPACITY OF 100% OF THE LIGHTING FIXTURE WEIGHT ACTING ANY DIRECTION. _4 TURNS IN 1" OF RUN, 2. FOR INTERMEDIATE DUTY CEILING SYSTEM, PROVIDE A SUPPLEMENTARY 12 GAUGE

HANGER ATTACHED TO THE GRID MEMBERS WITHIN 3" OF EACH CORNER OF EACH FIXTURE AS SHOWN ON DETAIL. TANDEM FIXTURES MAY UTILIZE COMMON WIRES. 3. FOR HEAVY DUTY CEILING SYSTEM, SUPPLEMENTARY HANGERS ARE NOT REQUIRED IF A 48" MODULAR HANGER WIRE PATTERN IS USED AND THE LIGHTING FIXTURE IS

SUPPORTED FROM MAIN TEES. SUPPLEMENTARY 12 GAUGE HANGERS ARE REQUIRED

WHERE THE FIXTURE IS SUPPORTED FROM CROSS TEES WITH LESS CARRYING CAPACITY THAN THE MAIN TEES. 4. LIGHTING FIXTURES WEIGHING LESS THAN 56 LBS. SHALL HAVE, IN ADDITION TO THE


REQUIREMENTS OUTLINED ABOVE, TWO 12 GAUGE HANGERS CONNECTED FROM THE FIXTURE HOUSING TO THE STRUCTURE ABOVE. THESE WIRES MAY BE SLACK.

5. LIGHTING FIXTURES WEIGHING 56 LBS. OR MORE SHALL BE SUPPORTED DIRECTLY FROM THE STRUCTURE ABOVE BY APPROVED HANGERS. 6. PENDANT HUNG LIGHTING FIXTURES SHALL BE SUPPORTED DIRECTLY FROM THE STRUCTURE ABOVE USING 9 GAUGE WIRES OR APPROVED ALTERNATE SUPPORT


1. COORDINATE SUPPORT REQUIREMENTS AND HANGER WIRE INSTALLATION WITH

WITHOUT USING CEILING SUSPENSION SYSTEM FOR DIRECT SUPPORT.


TYPICAL LIGHTING FIXTURE SUPPORT DETAIL NOT TO SCALE



MULTI-OUTLET ASSEMBLY DETAIL SCALE 1" = 1'-0"




POWER CONDUIT DETAIL



0 4" 8" 1


DATA CONDUIT DETAIL SCALE 1" = 1'-0"



PROJECTOR RACEWAY DETAIL

SCALE 1" = 1'-0"

5



HFSArchitects

NTERIORS **P**LANNING 1484 South State Salt Lake City, Utah 84115 801-596-0691/F: 596-0693

ARCHITECTURE

www.hfsa.com

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

MARK DATE DESCRIPTION DATE: 30 JANUARY 2008 AGENCY PROJECT NO: 07043640 HFSA PROJECT NO: 0730.01 CAD DWG FILE NO: 0730 E-601 dwg DRAWN BY: W.B.G.

R.G.K.

W.B.G.

ELECTRICAL

ARCHITECTURAL PHASE: **CONSTRUCTION DOCUMENTS**

SHEET TITLE


CHECKED BY:

DESIGNED BY:

DWG TYPE:

SYMBOL LIST, SCHEDULES AND DETAILS

E-601



8. TEST ALL SMOKE AND HEAT DETECTORS AFTER CLEANING AND PRIOR TO SUBSTANTIAL COMPLETION. TESTING SHALL BE PERFORMED BY A FACTORY AUTHORIZED AND TRAINED TECHNICIAN OF THE FIRE ALARM SYSTEM

9. TAKE ALL PRECAUTIONS NECESSARY TO AVOID DAMAGE TO THE EXISTING BUILDING. REPAIR ALL DAMAGE INCURRED BY DEMOLITION AND NEW CONSTRUCTION TO EXACTLY MATCH SURROUNDING SURFACES AND/OR CONDITIONS WITHOUT ADDITIONAL COST TO THE OWNER. COORDINATE REPAIRS WITH THE

HFSArchitects

ARCHITECTURE NTERIORS **P**LANNING 1484 South State

Salt Lake City, Utah 84115 801-596-0691/F: 596-0693 www.hfsa.com

CONSULTANT

ELECTRICAL

THOMAS & KOLKMAN ENG. CO. INC. 64 West 1700 South Salt Lake City, Utah 84115 801-484-8161/ F. 484-3538

SCIENCE BUILDING REMODEL

DIXIE STATE COLLEGE

ST. GEORGE, UTAH

| MARK | DATE | DESCRIPTION |
|----------|-------------|-----------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| DATE: | | 30 JANUARY 2008 |
| AGENCY | PROJECT NO: | 07043640 |
| HFSA PRO | DJECT NO: | 0730.01 |
| CAD DWG | FILE NO: | 0730 E-101.dwg |
| DRAWN B | Y: | W.B.G. |
| CHECKED | BY: | R.G.K. |

W.B.G.

ELECTRICAL

ARCHITECTURAL PHASE: CONSTRUCTION DOCUMENTS SHEET TITLE

DESIGNED BY:

DWG TYPE:

1ST FLOOR FIRE ALARM PLAN

FA101